

134949

County Stearns
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 02/09/1989
Update Date 02/14/2014
Received Date

Well Name HEIN, ROY	Township 125	Range 29	Dir W	Section 35	Subsection BCB	Well Depth 119 ft.	Depth Completed 119 ft.	Date Well Completed 05/18/1977
Elevation	Elev. Method					Drill Method Cable Tool	Drill Fluid	
Address C/W 15 CRESTVIEW RT#1 CT ST JOSEPH MN 56374						Use domestic	Status Active	
Stratigraphy Information Geological Material From To (ft.) Color Hardness SAND 0 40 BROWN CLAY 40 41 GRAY SAND 41 80 GRAY CLAY 80 83 GRAY WATER SAND 83 119 GRAY						Well Hydrofractured? Yes ☐ No ☐ From To		
						Casing Type Single casing Joint Threaded		
						Drive Shoe? Yes ☒ No ☐ Above/Below 1 ft.		
						Casing Diameter Weight 4 in. To 114. ft. 11 lbs./ft.		
						Open Hole From ft. To ft.		
						Screen? ☒ Type stainless Make JOHNSON Diameter Slot/Gauze Length Set 4 in. 20 5 ft. 114.5 ft. 119 ft.		
						Static Water Level 30 ft. land surface Measure 05/18/1977		
						Pumping Level (below land surface) 30 ft. 1 hrs. Pumping at 20 g.p.m.		
						Wellhead Completion Pitless adapter manufacturer Model ☐ Casing Protection ☐ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information Well Grouted? ☐ Yes ☒ No ☐ Not Specified		
Nearest Known Source of Contamination <u>67</u> feet <u>South</u> Direction <u>Septic tank/drain field</u> Type Well disinfected upon completion? ☒ Yes ☐ No								
Pump ☐ Not Installed Date Installed <u>06/17/1977</u> Manufacturer's name AERMOTOR Model Number <u>SD-12-75</u> HP <u>0.75</u> Volt <u>230</u> Length of drop pipe <u>84</u> ft Capacity g.p. Typ <u>Submersible</u>								
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☐ No								
Variance Was a variance granted from the MDH for this well? ☐ Yes ☐ No								
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date								
Angled Drill Hole								
Well Contractor Traut Well 73157 BAUMGART, B. Licensee Business Lic. or Reg. No. Name of Driller								