

178743

County Benton
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 09/08/1990
Update Date 02/14/2014
Received Date

Well Name GRANITE CITY					Township 37	Range 31	Dir W	Section 15	Subsection null	Well Depth 60 ft.		Depth Completed 57 ft.		Date Well Completed 04/29/1981													
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid															
Address										Use domestic		Status Active															
Contact BOX 854 ST CLOUD MN 56301										Well Hydrofractured?		Yes ☐		No ☐		From To											
Stratigraphy Information										Casing Type Single casing		Joint															
Geological Material										Drive Shoe?		Yes ☐		No ☐		Above/Below											
SAND										Casing Diameter		Weight															
CLAY										5 in. To		53 ft.		lbs./ft.													
SAND																											
SAND																											
										Open Hole		From		ft.		To		ft.									
										Screen? ☒		Type stainless		Make JOHNSON													
										Diameter		Slot/Gauze		Length		Set											
										4 in.		15		4 ft.		53 ft.		57 ft.									
										Static Water Level																	
										24 ft.		land surface		Measure		04/29/1981											
										Pumping Level (below land surface)																	
										ft.		1 hrs.		Pumping at		15		g.p.m.									
										Wellhead Completion																	
										Pitless adapter manufacturer										Model							
										☐ Casing Protection		☒ 12 in. above grade															
										☐ At-grade (Environmental Wells and Borings ONLY)																	
										Grouting Information										Well Grouted?		☐ Yes		☒ No		☐ Not Specified	
										Nearest Known Source of Contamination																	
										feet		Direction						Type									
										Well disinfected upon completion?		☒ Yes		☐ No													
										Pump ☐ Not Installed		Date Installed		08/10/1981													
										Manufacturer's name										DEMPSTER							
										Model Number		15-50		HP		0.5		Volt		230							
										Length of drop pipe		42		ft		Capacity		15		g.p.		Typ		Submersible			
										Abandoned																	
										Does property have any not in use and not sealed well(s)?										☐ Yes		☐ No					
										Variance																	
										Was a variance granted from the MDH for this well?										☐ Yes		☐ No					
										Miscellaneous																	
										First Bedrock										Aquifer							
										Last Strat										Depth to Bedrock				ft			
										Located by																	
										Locate Method																	
										System		UTM - NAD83, Zone 15, Meters		X		Y											
										Unique Number Verification										Input Date							
										Angled Drill Hole																	
										Well Contractor																	
										Traut Well		73157		SYLVESTER													
										Licensee Business		Lic. or Reg. No.		Name of Driller													