

180059

County Stearns
Quad Cold Spring
Quad ID 140B

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 04/17/1988
Update Date 02/14/2014
Received Date

Well Name DOUBECK,	Township 123	Range 30	Dir W	Section 9	Subsection AACCBD	Well Depth 110 ft.	Depth Completed 110 ft.	Date Well Completed 02/18/1981
Elevation 1210	Elev. Method 7.5 minute topographic map (+/- 5 feet)				Drill Method Non-specified Rotary	Drill Fluid		
Address C/W 24764 50 CR COLD SPRING MN 56320						Use domestic	Status Active	
						Well Hydrofractured? Yes ☐ No ☐	From	To
Stratigraphy Information						Casing Type Single casing	Joint	
						Drive Shoe? Yes ☐ No ☐	Above/Below	0 ft.
Geological Material						Casing Diameter	Weight	
SAND						5 in.	To 101 ft.	lbs./ft.
CLAY								
SAND								
						Open Hole	From	ft. To
						Screen? ☒	Type stainless	Make JOHNSON
						Diameter	Slot/Gauze	Length
						4 in.	15	9 ft.
							101 ft.	110 ft.
						Static Water Level		
						30 ft.	land surface	Measure 02/18/1981
						Pumping Level (below land surface)		
						70 ft.	hrs.	Pumping at 100 g.p.m.
						Wellhead Completion		
						Pitless adapter manufacturer	Model	
						☐ Casing Protection	☒ 12 in. above grade	
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information	Well Grouted?	☐ Yes ☒ No ☐ Not Specified
						Nearest Known Source of Contamination		
						60 feet	East Direction	Type
						Well disinfected upon completion?	☐ Yes ☐ No	
						Pump ☐ Not Installed	Date Installed	02/21/1981
						Manufacturer's name	DEMPCO	
						Model Number	20-100	HP 1
						Length of drop pipe	90 ft	Capacity g.p. Typ Submersible
						Abandoned		
						Does property have any not in use and not sealed well(s)?	☐ Yes ☐ No	
						Variance		
						Was a variance granted from the MDH for this well?	☐ Yes ☐ No	
						Miscellaneous		
						First Bedrock	Aquifer	Quat. buried
						Last Strat	sand-gray	Depth to Bedrock ft
						Located by	Minnesota Geological Survey	
						Locate Method	Digitized - scale 1:24,000 or larger (Digitizing Table)	
						System	UTM - NAD83, Zone 15, Meters	X 386609 Y 5037542
						Unique Number Verification	Information from	Input Date 01/01/1990
						Angled Drill Hole		
						Well Contractor		
						Traut Well	73157	SYLVESTER
						Licensee Business	Lic. or Reg. No.	Name of Driller