

184746

County Sherburne
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 04/17/1988
Update Date 04/14/2014
Received Date

Well Name AGB CONST	Township 35	Range 30	Dir W	Section 30	Subsection null	Well Depth 80 ft.	Depth Completed 80 ft.	Date Well Completed 07/07/1982
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid	
Address						Use domestic	Status Active	
C/W 104 ROOSEVELT RD ST CLOUD MN 56301						Well Hydrofractured? Yes ☐ No ☐ From To		
Stratigraphy Information						Casing Type Single casing	Joint	
						Drive Shoe? Yes ☐ No ☐	Above/Below 1.5 ft.	
Geological Material From To (ft.) Color Hardness						Casing Diameter Weight		
TOP SOIL 0 2 BLACK						0 in. To 37 ft. lbs./ft.		
SAND 2 30 BROWN								
GRAY CLAY 30 37 GRAY								
SAND 37 48 GRAY								
CLAY 48 80 GRAY								
MARROW 80 BLACK								
						Open Hole From ft. To ft.		
						Screen? ☒ Type plastic Make		
						Diameter Slot/Gauze Length Set		
						5 in. 20 10 ft. 37 ft. 48 ft.		
						Static Water Level		
						37 ft. land surface Measure 07/07/1982		
						Pumping Level (below land surface)		
						10 ft. 1 hrs. Pumping at 5 g.p.m.		
						Wellhead Completion		
						Pitless adapter manufacturer Model		
						☐ Casing Protection ☒ 12 in. above grade		
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
						Material Amount From To		
						0 ft. 25 ft.		
						Nearest Known Source of Contamination		
						feet Direction Type		
						Well disinfected upon completion? ☒ Yes ☐ No		
						Pump ☐ Not Installed Date Installed 08/04/1982		
						Manufacturer's name DEMPSTER		
						Model Number 10-50 HP 0.5 Volt 230		
						Length of drop pipe 60 ft Capacity 10 g.p. Typ Submersible		
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☐ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☐ No		
						Miscellaneous		
						First Bedrock Aquifer		
						Last Strat Depth to Bedrock ft		
						Located by		
						Locate Method		
						System UTM - NAD83, Zone 15, Meters X Y		
						Unique Number Verification Input Date		
						Angled Drill Hole		
						Well Contractor		
						Traut Well 73157 TRAUT, G.		
						Licensee Business Lic. or Reg. No. Name of Driller		