

188750

County Stearns
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 04/17/1988
Update Date 02/14/2014
Received Date

Well Name SAKRY, MIKE					Township 124		Range 28		Dir Section W 27		Subsection AD		Well Depth 80 ft.			Depth Completed 80 ft.			Date Well Completed 12/11/1981																
Elevation					Elev. Method								Drill Method Cable Tool			Drill Fluid																			
Address												Use domestic			Status Active																				
												Well Hydrofractured?						Yes ☐			No ☐			From			To								
												Casing Type Single casing						Joint Threaded																	
Stratigraphy Information Geological Material From To (ft.) Color Hardness CLAY SAND 0 15 BROWN MEDIUM SAND GRAVEL 15 20 BROWN MEDIUM SAND CLAY 20 25 BROWN MEDIUM HARDPAN 25 50 GRAY HARD HARDPAN 50 58 BROWN HARD SAND 58 68 BROWN MEDIUM SAND GRAVEL 68 80 BROWN MEDIUM												Drive Shoe?						Yes ☐			No ☐			Above/Below			2 ft.								
												Casing Diameter						Weight						Hole Diameter											
												4 in. To						76 ft. lbs./ft.						4 in. To 80 ft.											
												Open Hole												From			ft.			To			ft.		
												Screen? ☒			Type			Make			JOHNSON														
												Diameter			Slot/Gauze			Length			Set														
												4 in.			10			5 ft.			76 ft.			80 ft.											
												Static Water Level												30 ft.			land surface			Measure			12/11/1981		
												Pumping Level (below land surface)												35 ft.			1 hrs.			Pumping at			14 g.p.m.		
												Wellhead Completion												Pitless adapter manufacturer						Model					
☐ Casing Protection												☐ 12 in. above grade																							
☐ At-grade (Environmental Wells and Borings ONLY)																																			
Grouting Information												Well Grouted?			☐ Yes			☒ No			☐ Not Specified														
Nearest Known Source of Contamination												100 feet			North Direction			Septic tank/drain field Type																	
Well disinfected upon completion?												☒ Yes			☐ No																				
Pump ☐ Not Installed												Date Installed																							
Manufacturer's name												FLINT & WALLING																							
Model Number						5BA8		HP		0.5		Volt		230																					
Length of drop pipe						42 ft		Capacity		10 g.p.		Typ		Submersible																					
Abandoned												Does property have any not in use and not sealed well(s)?						☐ Yes			☐ No														
Variance												Was a variance granted from the MDH for this well?						☐ Yes			☐ No														
Miscellaneous												First Bedrock						Aquifer																	
Last Strat																		Depth to Bedrock						ft											
Located by																																			
Locate Method																																			
System						UTM - NAD83, Zone 15, Meters						X		Y																					
Unique Number Verification												Input Date																							
Angled Drill Hole																																			
Well Contractor												Fischer Well Co.						73135		EMSLANDER, R.															
Licensee Business												Lic. or Reg. No.		Name of Driller																					