

191801

County Stearns
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 04/17/1988
Update Date 02/14/2014
Received Date

Well Name BECKHAM,	Township 126	Range 30	Dir W	Section 31	Subsection null	Well Depth 114 ft.	Depth Completed 110 ft.	Date Well Completed 08/12/1982					
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid						
Address						Use domestic	Status Active						
						Well Hydrofractured?		Yes ☐	No ☐	From	To		
						Casing Type Single casing		Joint					
Stratigraphy Information Geological MaterialFromTo (ft.)ColorHardness SAND02BROWN SAND27GRAY CLAY & SILT767GRAY CLAY & SAND6772GRAY FINE SAND72110GRAY HARDPAN110114GRAY DECOMPOSED ROCK114WHITE						Drive Shoe?	Yes ☐	No ☒	Above/Below		2 ft.		
						Casing Diameter		Weight					
						5 in. To		102 ft.		lbs./ft.			
						Open Hole							
						From		ft.		To		ft.	
						Screen?	☒	Type	stainless		Make	JOHNSON	
						Diameter	Slot/Gauze	Length		Set			
						4 in.	15	8 ft.		102 ft.	110 ft.		
						Static Water Level							
						5 ft.		land surface		Measure	08/12/1982		
Pumping Level (below land surface)													
5 ft.		1 hrs.		Pumping at	25 g.p.m.								
Wellhead Completion													
Pitless adapter manufacturer						Model							
☐ Casing Protection						☐ 12 in. above grade							
☐ At-grade (Environmental Wells and Borings ONLY)													
Grouting Information						Well Grouted? ☒ Yes ☐ No ☐ Not Specified							
Material						Amount	From	To					
						0.5 Cubic yards	ft.	ft.					
Nearest Known Source of Contamination													
125 feet						East Direction		Septic tank/drain field Type					
Well disinfected upon completion?						☒ Yes	☐ No						
Pump ☐ Not Installed						Date Installed		08/13/1982					
Manufacturer's name						WEBTROL							
Model Number						HP	0.75	Volt	230				
Length of drop pipe						20 ft	Capacity	15 g.p.	Typ	Submersible			
Abandoned													
Does property have any not in use and not sealed well(s)?						☐ Yes ☒ No							
Variance													
Was a variance granted from the MDH for this well?						☐ Yes ☐ No							
Miscellaneous													
First Bedrock						Aquifer							
Last Strat						Depth to Bedrock			ft				
Located by													
Locate Method													
System						UTM - NAD83, Zone 15, Meters		X	Y				
Unique Number Verification						Input Date							
Angled Drill Hole													
Well Contractor													
Traut Well						73157		KEN					
Licensee Business						Lic. or Reg. No.		Name of Driller					