Minnesota Unique Well Number

192976

County Benton
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH

WELL AND BORING REPORT

Minnesota Statutes Chapter 1031

Entry Date 04/07/1988
Update Date 02/14/2014
Received Date

Well Name	Township	Range	Dir	Section	Subsection
FUCHS, GARY &	36	31	W	10	null

Elevation **Elev. Method**

Address

Contact 5.25 RIVERSIDE PO BOX 422 AV S SARTELL MN 56377

Stratigraphy Information

Geological Material	From	To (ft.)	Color	Hardness
CLAY	0	15	BROWN	M.HARD
ROCKS & BOULDERS	15	40	BROWN	HARD
SAND	40	75	BROWN	SOFT
GRAVEL	75	88	GRAY	SOFT

Remarks

Well Depth 88 ft. **Depth Completed** 88 ft. **Date Well Completed** 09/24/1982

Drill Method Non-specified Rotary **Drill Fluid**

Use domestic **Status** Active

Well Hydrofractured? **Yes** ☐ **No** ☐ **From** **To**

Casing Type Single casing **Joint**
Drive Shoe? **Yes** ☐ **No** ☐ **Above/Below** 3 ft.

Casing Diameter		Weight		Hole Diameter	
5 in. To	83 ft.	lbs./ft.		9 in. To	88 ft.

Open Hole From ft. To ft.

Screen? ☒ **Type** plastic **Make** CRESTLINE SLOTTED

Diameter	Slot/Gauze	Length	Set	
5 in.	28	15 ft.	83 ft.	88 ft.

Static Water Level
38 ft. land surface Measure 09/24/1982

Pumping Level (below land surface)
40 ft. 1 hrs. Pumping at 20 g.p.m.

Wellhead Completion
Pitless adapter manufacturer MAASS Model
☐ Casing Protection ☐ 12 in. above grade
☐ At-grade (Environmental Wells and Borings ONLY)

Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified

Material	Amount		From	To
neat cement	0.5	Cubic yards	0 ft.	60 ft.
cuttings			ft.	ft.

Nearest Known Source of Contamination
80 feet West Direction Septic tank/drain field Type
Well disinfected upon completion? ☒ Yes ☐ No

Pump ☐ Not Installed Date Installed 11/12/1982
Manufacturer's name FAIRBANKS
Model Number DS008 HP 0.5 Volt 230
Length of drop pipe 50 ft Capacity 10 g.p. Typ Submersible

Abandoned
Does property have any not in use and not sealed well(s)? ☐ Yes ☐ No

Variance
Was a variance granted from the MDH for this well? ☐ Yes ☐ No

Miscellaneous
First Bedrock Aquifer
Last Strat Depth to Bedrock ft
Located by
Locate Method
System UTM - NAD83, Zone 15, Meters X Y
Unique Number Verification Input Date

Angled Drill Hole

Well Contractor
Traut M.J. Well Co. 71536 KENNY
Licensee Business Lic. or Reg. No. Name of Driller