

198165

County Stearns
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 04/17/1988
Update Date 02/14/2014
Received Date

Well Name THOMPSON,					Township 126	Range 34	Dir W	Section null	Subsection null	Well Depth 48 ft.		Depth Completed 48 ft.		Date Well Completed 09/30/1985											
Elevation					Elev. Method					Drill Method Cable Tool		Drill Fluid													
Address										Use domestic		Status Active													
C/W SAUK CENTRE MN 56378										Well Hydrofractured?		Yes ☐		No ☐		From To									
Stratigraphy Information										Casing Type Single casing		Joint Threaded													
Geological Material										Drive Shoe?		Yes ☒		No ☐		Above/Below									
DIRT										Casing Diameter		Weight		Hole Diameter											
SAND										4 in. To		48 ft. 11 lbs./ft.		4 in. To 48 ft.											
PAN										28		30		HARD											
VEIN										30		37													
CLAY										37		46		BLUE		HARD									
SAND ON TOP OF										46		48													
										Open Hole		From		ft.		To		ft.							
										Screen?		☐		Type		Make									
										Static Water Level		15 ft.		land surface		Measure		09/30/1985							
										Pumping Level (below land surface)		21 ft.		6 hrs.		Pumping at		10 g.p.m.							
										Wellhead Completion		Pitless adapter manufacturer				Model									
										☐		Casing Protection		☐		12 in. above grade									
										☐		At-grade (Environmental Wells and Borings ONLY)													
										Grouting Information		Well Grouted?		☐		Yes		☒		No		☐		Not Specified	
										Nearest Known Source of Contamination		feet		Direction				Type							
										Well disinfected upon completion?		☒		Yes		☐		No							
										Pump		☐		Not Installed		Date Installed		09/30/1985							
										Manufacturer's name		FLINT & WALLING		Model Number		HP		0.5		Volt					
										Length of drop pipe		ft		Capacity		g.p.		Typ		Submersible					
										Abandoned		Does property have any not in use and not sealed well(s)?		☐		Yes		☐		No					
										Variance		Was a variance granted from the MDH for this well?		☐		Yes		☐		No					
										Miscellaneous		First Bedrock		Aquifer											
										Last Strat				Depth to Bedrock				ft							
										Located by		Locate Method		System		UTM - NAD83, Zone 15, Meters		X		Y					
										Unique Number Verification				Input Date											
										Angled Drill Hole															
										Well Contractor		Licensee Business		Lic. or Reg. No.		JOHNSON, L		Name of Driller							