

236700

County

Swift

Quad

Quad ID

MINNESOTA DEPARTMENT OF HEALTH

WELL AND BORING REPORT

Minnesota Statutes Chapter 1031

Entry Date04/17/1988

Update Date02/14/2014

Received Date

Well NameTownshipRangeDir SectionSubsection SMITH, LESTER12139W 4C					Well DepthDepth CompletedDate Well Completed 120 ft.120 ft.07/11/1977																										
ElevationElev. Method					Drill MethodNon-specified RotaryDrill Fluid																										
Address C/WBENSON MN 56215					Use domesticStatusActive																										
Stratigraphy Information <table><thead><tr><th>Geological Material</th><th>From</th><th>To (ft.)</th><th>Color</th><th>Hardness</th></tr></thead><tbody><tr><td>BLACK DIRT</td><td>0</td><td>2</td><td></td><td></td></tr><tr><td>YELLOW CLAY</td><td>2</td><td>25</td><td></td><td></td></tr><tr><td>BLUE CLAY</td><td>25</td><td>100</td><td></td><td></td></tr><tr><td>SAND</td><td>100</td><td>120</td><td></td><td></td></tr></tbody></table>					Geological Material	From	To (ft.)	Color	Hardness	BLACK DIRT	0	2			YELLOW CLAY	2	25			BLUE CLAY	25	100			SAND	100	120			Well Hydrofractured?YesNoFromTo	
					Geological Material	From	To (ft.)	Color	Hardness																						
					BLACK DIRT	0	2																								
					YELLOW CLAY	2	25																								
					BLUE CLAY	25	100																								
					SAND	100	120																								
					Casing TypeSingle casingJoint																										
					Drive Shoe?YesNoAbove/Below																										
					Casing DiameterWeight 4 in. To ft. lbs./ft.																										
					Open HoleFrom ft. To ft.																										
Screen?☒Type stainlessMake DiameterSlot/GauzeLengthSet 4 in.5 ft. ft. ft.																															
Static Water Level 50 ft. land surfaceMeasure07/11/1977																															
Pumping Level (below land surface) 65 ft. hrs. Pumping at80 g.p.m.																															
Wellhead Completion Pitless adapter manufacturerModel ☐ Casing Protection☐ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)																															
Grouting InformationWell Grouted?☐ Yes☐ No☒ Not Specified																															
Nearest Known Source of Contamination feetDirectionType Well disinfected upon completion?☐ Yes☐ No																															
Pump☐ Not InstalledDate Installed Manufacturer's name Model NumberHPVolt Length of drop pipe84 ft Capacity g.p. Typ																															
Abandoned Does property have any not in use and not sealed well(s)?☐ Yes☐ No																															
Variance Was a variance granted from the MDH for this well?☐ Yes☐ No																															
Miscellaneous First BedrockAquifer Last StratDepth to Bedrockft Located by Locate Method SystemUTM - NAD83, Zone 15, MetersXY Unique Number VerificationInput Date																															
Angled Drill Hole																															
Well Contractor Steffl Well Co.61335STEFFL WELL Licensee BusinessLic. or Reg. No.Name of Driller																															