

456028

County Stearns
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 06/10/1991
Update Date 02/14/2014
Received Date

Well Name JENSON, TOM	Township 124	Range 28	Dir W	Section 5	Subsection DC	Well Depth 68 ft.	Depth Completed 68 ft.	Date Well Completed 04/05/1989
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
Contact 604 4TH ST NE SARTELL MN 56377						Well Hydrofractured? Yes ☐ No ☐ From To		
Well 5643 WESTOAKES DR MN						Casing Type Single casing Joint Glued		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☐ Above/Below 2 ft.		
Geological Material From To (ft.) Color Hardness						Casing Diameter Weight		
COARSE SAND, 0 33 BROWN SOFT						4 in. To 64 ft. lbs./ft.		
SAND & GRAVEL 33 68 GRAY SOFT								
						Open Hole From ft. To ft.		
						Screen? ☒ Type stainless Make JOHNSON		
						Diameter Slot/Gauze Length Set		
						4 in. 18 4 ft. 64 ft. 68 ft.		
						Static Water Level		
						10 ft. land surface Measure 04/05/1989		
						Pumping Level (below land surface)		
						60 ft. 1 hrs. Pumping at 100 g.p.m.		
						Wellhead Completion		
						Pitless adapter manufacturer MAAS Model 4J		
						☐ Casing Protection ☒ 12 in. above grade		
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
						Material Amount From To		
						neat cement 7 ft. 37 ft.		
						Nearest Known Source of Contamination		
						feet Direction Type		
						Well disinfected upon completion? ☒ Yes ☐ No		
						Pump ☐ Not Installed Date Installed 06/08/1989		
						Manufacturer's name AERMOTOR		
						Model Number A12B50 HP 0.5 Volt 230		
						Length of drop pipe 40 ft Capacity 12 g.p. Typ		
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☐ No		
						Miscellaneous		
						First Bedrock Aquifer		
						Last Strat Depth to Bedrock ft		
						Located by		
						Locate Method		
						System UTM - NAD83, Zone 15, Meters X Y		
						Unique Number Verification Input Date		
						Angled Drill Hole		
						Well Contractor		
						Traut M.J. Well Co. 71536 BRUCE & MARK		
						Licensee Business Lic. or Reg. No. Name of Driller		