

486432

County Stearns
Quad Albany
Quad ID 158A

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 10/13/1991
Update Date 02/14/2014
Received Date

Well Name LOBITZ, MIKE					Township 125	Range 30	Dir W	Section 6	Subsection BBDCBB	Well Depth 91 ft.				Depth Completed 91 ft.				Date Well Completed 04/30/1991			
Elevation 1151					Elev. Method 7.5 minute topographic map (+/- 5 feet)					Drill Method Non-specified Rotary				Drill Fluid Revert							
Address C/W 37782 SUNNYFIELD CI ST CLOUD MN 56301										Use domestic				Status Active							
Stratigraphy Information										Well Hydrofractured? Yes ☐ No ☐				From To							
										Casing Type Single casing				Joint Glued							
										Drive Shoe? Yes ☐ No ☒				Above/Below 1 ft.							
Geological Material										Casing Diameter				Weight							
SANDY CLAY										4 in. To				90 ft. lbs./ft.							
SANDY GRAVEL										14				29							
SANDY CLAY										29				36							
SANDY GRAVEL										36				44							
SANDY CLAY										44				80							
SAND & GRAVEL										80				88							
SANDY CLAY										88				91							
										Open Hole				From ft. To ft.							
										Screen? ☒				Type plastic				Make JOHNSON			
										Diameter				Slot/Gauze				Length			
										4 in.				20				4 ft.			
														84 ft.				88 ft.			
										Static Water Level											
										28 ft.				land surface				Measure 04/30/1991			
										Pumping Level (below land surface)											
										80 ft.				hrs.				Pumping at 30 g.p.m.			
										Wellhead Completion											
										Pitless adapter manufacturer								Model			
										☐ Casing Protection				☒ 12 in. above grade							
										☐ At-grade (Environmental Wells and Borings ONLY)											
										Grouting Information				Well Grouted? ☒ Yes ☐ No ☐ Not Specified							
										Material				Amount				From To			
										neat cement				0				3 ft. 35 ft.			
										bentonite				0				35 ft. 72 ft.			
										Nearest Known Source of Contamination											
										102 feet				South Direction				Septic tank/drain field Type			
										Well disinfected upon completion?				☐ Yes ☐ No							
										Pump ☐ Not Installed				Date Installed				07/00/1990			
										Manufacturer's name				AERMOTOR							
										Model Number				A12B50				HP 0.5			
										Length of drop pipe				60 ft				Capacity 12 g.p.			
																		Typ Submersible			
										Abandoned											
										Does property have any not in use and not sealed well(s)?				☐ Yes ☐ No							
										Variance											
										Was a variance granted from the MDH for this well?				☐ Yes ☐ No							
										Miscellaneous											
										First Bedrock				Aquifer				Quat. buried			
										Last Strat				clay+sand-gray				Depth to Bedrock ft			
										Located by				Minnesota Geological Survey							
										Locate Method				Digitized - scale 1:24,000 or larger (Digitizing Table)							
										System				UTM - NAD83, Zone 15, Meters				X 382504 Y 5058537			
										Unique Number Verification				Name on mailbox				Input Date 01/01/1990			
										Angled Drill Hole											
										Well Contractor											
										Traut M.J. Well Co.				71536				JEFF/JEFF			
										Licensee Business				Lic. or Reg. No.				Name of Driller			