

542697

County Itasca
Quad Elmwood
Quad ID 356C

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 04/11/1996
Update Date 01/08/2026
Received Date

Well Name TAYLOR, LOUIS					Township 150	Range 28	Dir W	Section 15	Subsection BAABDC
Elevation 1408					Elev. Method 7.5 minute topographic map (+/- 5 feet)				
Address Well 64536 SANDY BEACH RD NORTHOME MN Contact NORTHOME MN 56661									
Stratigraphy Information									
Geological Material		From	To (ft.)	Color	Hardness				
SANDY CLAY		0	8	BROWN	MEDIUM				
CLAY		8	24	BROWN	MEDIUM				
CLAY		24	75	GRAY	MEDIUM				
FINE SILT SAND		75	170	GRAY	SOFT				
CLAY ROCK		170	178	GRAY	HARD				
SAND-GRAVEL		178	185	BROWN	MEDIUM				
Well Depth 185 ft.									
Depth Completed 185 ft.									
Date Well Completed 05/31/1995									
Drill Method Non-specified Rotary									
Drill Fluid Bentonite									
Use domestic									
Status Active									
Well Hydrofractured? Yes ☐ No ☐ From To									
Casing Type Single casing									
Joint									
Drive Shoe? Yes ☐ No ☒ Above/Below									
Casing Diameter 4 in. To 181 ft.									
Weight lbs./ft.									
Hole Diameter 8 in. To 185 ft.									
Open Hole From ft. To ft.									
Screen? ☒ Type stainless Make JOHNSON									
Diameter Slot/Gauze Length Set									
2 in. 12 4 ft. 181 ft. 185 ft.									
Static Water Level 24 ft. land surface Measure 05/31/1995									
Pumping Level (below land surface) 40 ft. 1 hrs. Pumping at 12 g.p.m.									
Wellhead Completion Pitless adapter manufacturer MONITOR Model SNAPPY									
☐ Casing Protection ☐ 12 in. above grade									
☐ At-grade (Environmental Wells and Borings ONLY)									
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified									
Material Amount From To									
bentonite 2 Sacks 8 ft. 30 ft.									
Nearest Known Source of Contamination 100 feet East Direction Septic tank/drain field Type									
Well disinfected upon completion? ☒ Yes ☐ No									
Pump ☐ Not Installed Date Installed 06/01/1995									
Manufacturer's name MYERS									
Model Number HP 0.5 Volt 230									
Length of drop pipe 100 ft Capacity 10 g.p. Typ Submersible									
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No									
Variance Was a variance granted from the MDH for this well? ☐ Yes ☐ No									
Miscellaneous First Bedrock Aquifer Quat. buried									
Last Strat sand +larger-brown Depth to Bedrock ft									
Located by Itasca Cty. Soil & Water Cons. Dist.									
Locate Method GPS SA Off (averaged) (15 meters)									
System UTM - NAD83, Zone 15, Meters X 408979 Y 5296568									
Unique Number Verification Tag on well Input Date 10/23/2000									
Angled Drill Hole									
Well Contractor Aqua Well Drilling 04463 PLATT, R.									
Licensee Business Lic. or Reg. No. Name of Driller									