

544464

County Washington
Quad St Paul Park
Quad ID 102C

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date01/13/1997

Update Date04/09/2014

Received Date

Well Name DRESS,					Township 28	Range 21	Dir Section W 31	Subsection CDBBBA	Well Depth 460 ft.				Depth Completed 460 ft.				Date Well Completed 07/14/1994			
Elevation 985 ft.					Elev. Method 7.5 minute topographic map (+/- 5 feet)					Drill Method Non-specified Rotary				Drill Fluid						
Address C/W 6134 KALEN CT WOODBURY MN 55125									Use domestic								Status Active			
Stratigraphy Information Geological Material From To (ft.) Color Hardness CLAY & GRAVEL 0 72 BROWN HARD LIMEROCK 72 95 BROWN HARD SANDROCK 95 230 WHITE MED-HRD LIMEROCK 230 395 BROWN HARD SANDROCK 395 460 WHITE HARD									Well Hydrofractured? Yes ☐ No ☐ From To											
									Casing Type Single casing								Joint Welded			
									Drive Shoe? Yes ☒ No ☐								Above/Below			
									Casing Diameter 4 in. To				Weight 440 ft. 10.79 lbs./ft.				Hole Diameter 12 in. To 73 ft. 8 in. To 440 ft. 4 in. To 460 ft.			
									Open Hole From 440 ft. To 460 ft.											
									Screen? ☐ Type Make											
									Static Water Level 270 ft. land surface Measure 07/13/1994											
									Pumping Level (below land surface) 285 ft. 1 hrs. Pumping at 30 g.p.m.											
									Wellhead Completion Pitless adapter manufacturer SNAPPY Model ☐ Casing Protection ☐ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)											
									Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To neat cement 0 Sacks 0 ft. 420 ft.											
Nearest Known Source of Contamination 43 feet South Direction Well disinfected upon completion? ☒ Yes ☐ No Septic tank/drain field Type																				
Pump ☐ Not Installed Date Installed 07/14/1994 Manufacturer's name STA-RITE Model Number 10P4F02T HP 1.5 Volt 230 Length of drop pipe 300 ft Capacity 12 g.p. Typ Submersible																				
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No																				
Variance Was a variance granted from the MDH for this well? ☐ Yes ☐ No																				
Miscellaneous First Bedrock Platteville Formation Aquifer Jordan Last Strat Jordan Sandstone Depth to Bedrock 72 ft Located by Minnesota Geological Survey Locate Method Digitization (Screen) - Map (1:24,000) (15 meters or System UTM - NAD83, Zone 15, Meters X 501679 Y 4967993 Unique Number Verification Address verification Input Date 03/08/2002																				
Angled Drill Hole																				
Well Contractor Schroepfer Well Co. 62119 MAHER, T. Licensee Business Lic. or Reg. No. Name of Driller																				