

548063

County Stearns
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 02/24/1995
Update Date 02/14/2014
Received Date

Well Name JIM NOTCH	Township 126	Range 32	Dir W	Section 33	Subsection ADC	Well Depth 84 ft.	Depth Completed 84 ft.	Date Well Completed 08/25/1994
Elevation	Elev. Method					Drill Method Cable Tool	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
Contact 26673 30 CR ALBANY MN 56307						Well Hydrofractured? Yes ☐ No ☐ From To		
Well KINGS LAKE RD FREEPORT MN 56331						Casing Type Single casing Joint		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter		
CLAY		0	18	BROWN	SOFT	5 in. To 80 ft. lbs./ft. 9 in. To 84 ft.		
SAND		18	38	BROWN	SOFT			
CLAY		38	41	YELLOW	MEDIUM			
SAND		41	43	BROWN	SOFT			
CLAY		43	55	BLUE	HARD			
SAND		55	56	WHITE	HARD			
CLAY		56	71	BLUE	MEDIUM			
SAND		71	72	GRAY	HARD			
CLAY		72	80	BLUE	HARD			
SAND		80		GRAY				
						Open Hole From ft. To ft.		
						Screen? ☒ Type stainless Make JOHNSON		
						Diameter Slot/Gauze Length Set		
						5 in. 12 4 ft. 80 ft. 84 ft.		
						Static Water Level		
						35 ft. land surface Measure 08/25/1994		
						Pumping Level (below land surface)		
						40 ft. 1 hrs. Pumping at 10 g.p.m.		
						Wellhead Completion		
						Pitless adapter manufacturer Model		
						☐ Casing Protection ☐ 12 in. above grade		
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
						Material Amount From To		
						bentonite 0 ft. 79 ft.		
						Nearest Known Source of Contamination		
						200 feet Direction Type		
						Well disinfected upon completion? ☒ Yes ☐ No		
						Pump ☐ Not Installed Date Installed		
						Manufacturer's name		
						Model Number HP Volt		
						Length of drop pipe ft Capacity g.p. Typ		
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☐ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☐ No		
						Miscellaneous		
						First Bedrock Aquifer		
						Last Strat Depth to Bedrock ft		
						Located by		
						Locate Method		
						System UTM - NAD83, Zone 15, Meters X Y		
						Unique Number Verification Input Date		
						Angled Drill Hole		
						Well Contractor		
						Atkinson Well Co. 73025 ATKINSON, K.		
						Licensee Business Lic. or Reg. No. Name of Driller		