

561453

County Stearns
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 01/16/1996
Update Date 02/14/2014
Received Date

Well Name AVON LUMBER	Township 123	Range 28	Dir W	Section 7	Subsection null	Well Depth 40 ft.	Depth Completed 35 ft.	Date Well Completed 07/17/1995
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
Well 24052 68TH AV S ST CLOUD MN 56301						Well Hydrofractured? Yes ☐ No ☐ From To		
Contact P.O. BOX 7 AVON MN 56310						Casing Type Single casing Joint		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☐ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter		
TOPSOIL		0	2			4 in. To 31 ft. lbs./ft. 6.5 in. To 40 ft.		
SAND		2	20	BROWN				
SAND & GRAVEL		20	40	GRAY				
Open Hole						From	ft.	To
Screen? ☒						Type plastic	Make JOHNSON	
Diameter						Slot/Gauze	Length	Set
4 in.						12	4 ft.	31 ft. 35 ft.
Static Water Level								
7 ft.						land surface	Measure	07/17/1995
Pumping Level (below land surface)								
35 ft.						1 hrs.	Pumping at	40 g.p.m.
Wellhead Completion								
Pitless adapter manufacturer						MAAS	Model 4J1	
☐ Casing Protection						☒ 12 in. above grade		
☐ At-grade (Environmental Wells and Borings ONLY)								
Grouting Information						Well Grouted?	☒ Yes ☐ No ☐ Not Specified	
Material						Amount	From	To
bentonite							0	ft. 25 ft.
Nearest Known Source of Contamination								
118 feet						Southeas Direction	Septic tank/drain field Type	
Well disinfected upon completion?						☒ Yes	☐ No	
Pump ☐ Not Installed						Date Installed	08/17/1995	
Manufacturer's name						AERMOTOR		
Model Number						A12B50	HP	0.5
Length of drop pipe						20	ft	Capacity 12 g.p.
Abandoned								
Does property have any not in use and not sealed well(s)?						☐ Yes	☒ No	
Variance								
Was a variance granted from the MDH for this well?						☐ Yes	☐ No	
Miscellaneous								
First Bedrock						Aquifer		
Last Strat						Depth to Bedrock		
Located by						ft		
Locate Method								
System						UTM - NAD83, Zone 15, Meters	X	Y
Unique Number Verification						Input Date		
Angled Drill Hole								
Well Contractor								
Traut M.J. Well Co.						71536	SHELDON	
Licensee Business						Lic. or Reg. No.	Name of Driller	