

574590

County Carlton
Quad Esko
Quad ID 224A

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 08/21/1996
Update Date
Received Date

Well Name PICCONATTO,					Township 49	Range 16	Dir W	Section 25	Subsection CDABDB	Well Depth 105 ft.				Depth Completed 105 ft.				Date Well Completed 05/31/1996			
Elevation 1109					Elev. Method 7.5 minute topographic map (+/- 5 feet)					Drill Method Non-specified Rotary				Drill Fluid Bentonite							
Address										Use domestic				Status Active							
Contact 71 STENMAN RD ESKO MN 55733										Well Hydrofractured? Yes ☐ No ☐				From To							
Stratigraphy Information										Casing Type Single casing				Joint Threaded							
Geological Material										Drive Shoe? Yes ☒ No ☐				Above/Below							
FILL										Casing Diameter 6 in. To 82 ft. 19 lbs./ft.				Hole Diameter 9 in. To 82 ft. 6 in. To 105 ft.							
CLAY																					
ROCKS, SANDY CLAY																					
STICKY CLAY																					
CLAY																					
SLATE																					
										Open Hole From 82 ft. To 105 ft.											
										Screen? ☐				Type Make							
										Static Water Level 38 ft. land surface Measure 03/15/1996											
										Pumping Level (below land surface) 75 ft. 1 hrs. Pumping at 15 g.p.m.											
										Wellhead Completion Pitless adapter manufacturer MONITOR Model SNAPPY ☐ Casing Protection ☒ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)											
										Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To bentonite 2 Sacks 0 ft. 30 ft.											
										Nearest Known Source of Contamination 50 feet Direction Septic tank/drain field Type Well disinfected upon completion? ☒ Yes ☐ No											
										Pump ☐ Not Installed Date Installed 05/31/1996 Manufacturer's name GOULDS Model Number 10GS07412 HP 0.75 Volt 230 Length of drop pipe 81 ft Capacity 10 g.p. Typ Submersible											
										Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No											
										Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No											
										Miscellaneous First Bedrock Virginia/Thomson Aquifer Virginia/Thomson Last Strat Virginia/Thomson Depth to Bedrock 80 ft Located by Carlton Cty. Soil & Water Cons. Dist. Locate Method GPS Differentially Corrected (25 meters) System UTM - NAD83, Zone 15, Meters X 552485 Y 5171477 Unique Number Verification Input Date 07/20/2000											
										Angled Drill Hole											
										Well Contractor Rosga Well Co. 58069 FRYE, F. Licensee Business Lic. or Reg. No. Name of Driller											
Remarks																					