

595557

County Pine
Quad Beroun
Quad ID 170B

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 05/29/1998
Update Date 02/14/2014
Received Date

Well Name MOHR,	Township 40	Range 21	Dir W	Section 16	Subsection ABA	Well Depth 90 ft.	Depth Completed 90 ft.	Date Well Completed 09/17/1997
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
Contact 505 6TH ST PINE CITY MN 55063						Well Hydrofractured? Yes ☐ No ☐ From To		
Well RR 2 BOX 13M BROOK PARK MN 55007						Casing Type Single casing Joint		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☐ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter		
TOP SOIL		0	2	BLACK	SOFT	4 in. To 80 ft. lbs./ft. 6.5 in. To 90 ft.		
CLAY		2	14	YELLOW	MEDIUM			
SAND		14	23	RED	SOFT			
CLAY & COBBLES		23	80	RED	HARD			
SAND & GRAVEL		80	90	BROWN	SOFT			
Open Hole						From	ft.	To ft.
Screen? ☒						Type plastic	Make BIG FOOT	
Diameter						Slot/Gauze	Length	Set
4 in.						16	10 ft.	80 ft. 90 ft.
Static Water Level								
14 ft.						land surface	Measure	09/17/1997
Pumping Level (below land surface)								
Wellhead Completion								
Pitless adapter manufacturer						BAKER	Model SNAPPY	
☐ Casing Protection						☒ 12 in. above grade		
☐ At-grade (Environmental Wells and Borings ONLY)								
Grouting Information						Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
Material						Amount	From	To
bentonite						2 Sacks	0 ft.	30 ft.
Nearest Known Source of Contamination								
62 feet						Northeas Direction		Septic tank/drain field Type
Well disinfected upon completion?						☒ Yes ☐ No		
Pump ☐ Not Installed						Date Installed	09/17/1997	
Manufacturer's name						AERMOTOR		
Model Number						HP	0.5	Volt 220
Length of drop pipe						60 ft	Capacity 12 g.p.	Typ Submersible
Abandoned								
Does property have any not in use and not sealed well(s)?						☐ Yes ☒ No		
Variance								
Was a variance granted from the MDH for this well?						☐ Yes ☒ No		
Miscellaneous								
First Bedrock						Aquifer		
Last Strat						Depth to Bedrock ft		
Located by								
Locate Method								
System UTM - NAD83, Zone 15, Meters						X	Y	
Unique Number Verification						Input Date		
Angled Drill Hole								
Well Contractor								
J. D. Well Service						13606	MILTON II, J	
Licensee Business						Lic. or Reg. No.	Name of Driller	