

595962

County Stearns
Quad Rockville
Quad ID 140A

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 10/01/1998
Update Date 01/06/2005
Received Date

Well Name DOLL, DAN					Township 123	Range 29	Dir W	Section 2	Subsection null	Well Depth 49 ft.			Depth Completed 49 ft.			Date Well Completed 05/08/1997								
Elevation 1129					Elev. Method Calc from DEM (USGS 7.5 min or equiv.)					Drill Method Non-specified Rotary			Drill Fluid Bentonite											
Address C/W 25707 BURG ST ST CLOUD MN 56301										Use domestic			Status Active											
Stratigraphy Information Geological Material From To (ft.) Color Hardness CLAY & ROCK 0 21 BROWN MEDIUM CLAY 21 44 GRAY MEDIUM SAND 44 49 BROWN MEDIUM										Well Hydrofractured? Yes ☐ No ☐			From To											
										Casing Type Single casing			Joint											
										Drive Shoe? Yes ☐ No ☐			Above/Below											
										Casing Diameter 4 in. To 44 ft.			Weight lbs./ft.			Hole Diameter 8.8 in. To 49 ft.								
										Open Hole From ft. To ft.														
										Screen? ☒			Type plastic			Make JAYCO								
										Diameter 4 in.			Slot/Gauze 15			Length 5 ft.			Set 44 ft. 49 ft.					
										Static Water Level														
										Pumping Level (below land surface) ft. 1 hrs. Pumping at 6 g.p.m.														
										Wellhead Completion Pitless adapter manufacturer MONITOR Model SNAPPY ☐ Casing Protection ☒ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)														
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To bentonite 3 Cubic yards 0 ft. 44 ft.																								
Nearest Known Source of Contamination 100 feet Northwes Direction Septic tank/drain field Type Well disinfected upon completion? ☐ Yes ☐ No																								
Pump ☐ Not Installed Date Installed 09/15/1997 Manufacturer's name AERMOTOR Model Number SD1250 HP 0.5 Volt 230 Length of drop pipe ft Capacity 12 g.p. Typ Submersible																								
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No																								
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No																								
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Minnesota Department of Health Locate Method Digitization (Screen) - Map (1:24,000) (15 meters or System UTM - NAD83, Zone 15, Meters X 398390 Y 5038858 Unique Number Verification Info/GPS from data Input Date 05/16/2001																								
Angled Drill Hole																								
Well Contractor Fischer Well Co. 73135 JACK FISCHER Licensee Business Lic. or Reg. No. Name of Driller																								