

597537

County Isanti
Quad Wyanett
Quad ID 153C

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 06/21/2000
Update Date 08/15/2014
Received Date 08/22/1997

Well Name STOLKA, JAMES					Township 36		Range 25		Dir Section W 26		Subsection CDCCDA			
Elevation 927 ft.					Elev. Method		LiDAR 1m DEM (MNDNR)							
Address														
Well 33324 XENON DR NW PRINCETON MN 55371														
Stratigraphy Information														
Geological Material		From	To (ft.)	Color	Hardness									
SAND		0	35	BROWN										
SANDY CLAY		35	42	BROWN										
SAND & GRAVEL		42	50	BRN/BLK										
WATER & SAND		50	57	BROWN										
Well Depth 57 ft.					Depth Completed 57 ft.			Date Well Completed 08/04/1997						
Drill Method Non-specified Rotary					Drill Fluid Bentonite									
Use domestic								Status Active						
Well Hydrofractured?					Yes ☐		No ☒		From To					
Casing Type Single casing								Joint Unknown						
Drive Shoe?					Yes ☐		No ☒		Above/Below					
Casing Diameter					Weight			Hole Diameter						
4 in.		To	53 ft.	lbs./ft.				8.5 in.		To	57 ft.			
Open Hole														
		From		ft.		To		ft.						
Screen? ☒				Type stainless		Make WESCO								
Diameter		Slot/Gauze		Length		Set								
4 in.		10		4 ft.		53 ft.		57 ft.						
Static Water Level														
4 ft.		land surface				Measure		07/28/1997						
Pumping Level (below land surface)														
		ft.		hrs.		Pumping at		15 g.p.m.						
Wellhead Completion														
Pitless adapter manufacturer					Model									
☐		Casing Protection		☐		12 in. above grade								
☐		At-grade (Environmental Wells and Borings ONLY)												
Grouting Information					Well Grouted?		☒ Yes ☐ No ☐ Not Specified							
Material				Amount		From		To						
high solids bentonite				4 Sacks		0 ft.		30 ft.						
Nearest Known Source of Contamination														
55 feet		Northwes		Direction		Septic tank/drain field		Type						
Well disinfected upon completion?					☒ Yes ☐ No									
Pump ☐ Not Installed					Date Installed		08/04/1997							
Manufacturer's name					STA-RITE									
Model Number					HP 0.5		Volt							
Length of drop pipe					40 ft		Capacity		g.p.		Typ Submersible			
Abandoned														
Does property have any not in use and not sealed well(s)?					☐ Yes ☒ No									
Variance														
Was a variance granted from the MDH for this well?					☐ Yes ☒ No									
Miscellaneous														
First Bedrock					Aquifer		Quat. Water							
Last Strat					sand-brown		Depth to Bedrock		ft					
Located by					Minnesota Geological Survey									
Locate Method					GPS SA Off (averaged) (15 meters)									
System					UTM - NAD83, Zone 15, Meters		X 466936		Y 5046678					
Unique Number Verification					Address verification		Input Date		07/22/2014					
Angled Drill Hole														
Well Contractor														
Torgerson Well Co.					27056		JORGENSON, D							
Licensee Business					Lic. or Reg. No.		Name of Driller							