

600456

County Stearns
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 09/29/1998
Update Date 02/14/2014
Received Date

Well Name MAXY, BERNIE					Township 122	Range 27	Dir W	Section 8	Subsection ABB	Well Depth 61 ft.		Depth Completed 61 ft.		Date Well Completed 07/31/1997													
Elevation					Elev. Method					Drill Method Cable Tool		Drill Fluid Bentonite															
Address										Use domestic		Status Active															
C/W 497 EMMEH RD CLEARWATER MN 55320										Well Hydrofractured?		Yes ☐		No ☐		From		To									
Stratigraphy Information Geological Material From To (ft.) Color Hardness CLAY 0 12 BROWN MEDIUM SILT 12 22 GRAY MEDIUM CLAY 22 31 GRAY MEDIUM SAND 31 61 GRAY MEDIUM										Casing Type Single casing		Joint															
										Drive Shoe?		Yes ☒		No ☐		Above/Below											
										Casing Diameter		Weight						Hole Diameter									
										4 in. To		56 ft. 11		lbs./ft.				4.5 in. To		61 ft.							
										Open Hole										From		ft.		To		ft.	
										Screen? ☒		Type stainless		Make JOHNSON													
										Diameter		Slot/Gauze		Length		Set											
										4 in.		10		5 ft.		56 ft.		61 ft.									
										Static Water Level										10 ft.		land surface		Measure		07/31/1997	
										Pumping Level (below land surface)										20 ft.		1 hrs.		Pumping at		10 g.p.m.	
Wellhead Completion										Pitless adapter manufacturer		MONITOR		Model		SNAPPY											
☐ Casing Protection										☒ 12 in. above grade																	
☐ At-grade (Environmental Wells and Borings ONLY)																											
Grouting Information										Well Grouted?		☒ Yes		☐ No		☐ Not Specified											
Material										Amount		From		To													
bentonite										3 Cubic yards		0 ft.		ft.													
Nearest Known Source of Contamination										75 feet		West Direction		Septic tank/drain field		Type											
Well disinfected upon completion?										☒ Yes		☐ No															
Pump ☐ Not Installed										Date Installed		08/01/1997															
Manufacturer's name										AERMOTOR																	
Model Number										SD-12-50		HP		0.5		Volt		230									
Length of drop pipe										30 ft		Capacity		12 g.p.		Typ		Submersible									
Abandoned										Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No																	
Variance										Was a variance granted from the MDH for this well? ☐ Yes ☒ No																	
Miscellaneous										First Bedrock										Aquifer							
Last Strat										Depth to Bedrock										ft							
Located by																											
Locate Method																											
System										UTM - NAD83, Zone 15, Meters		X		Y													
Unique Number Verification										Input Date																	
Angled Drill Hole																											
Well Contractor										Fischer Well Co.										73135		DONABAUER, D.					
Licensee Business										Lic. or Reg. No.												Name of Driller					