

630168

County Beltrami
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 01/02/2001
Update Date 03/11/2005
Received Date

Well Name TUERSTOL,	Township 147	Range 34	Dir Section W 24	Subsection BAB	Well Depth 64 ft.	Depth Completed 64 ft.	Date Well Completed 03/27/2000
Elevation	Elev. Method				Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address C/W 4120 MAYFLOWER RD NW BEMIDJI MN 56601					Use domestic	Status Active	
Stratigraphy Information Geological Material From To (ft.) Color Hardness SAND 0 30 BROWN MEDIUM GRAVEL 30 35 BROWN MEDIUM CLAY 35 58 GRAY HARD SAND 58 64 GRAY MEDIUM					Well Hydrofractured? Yes ☐ No ☒ From To		
					Casing Type Single casing Joint Unknown		
					Drive Shoe? Yes ☐ No ☒ Above/Below		
					Casing Diameter Weight Hole Diameter 4 in. To 60 ft. lbs./ft. 8 in. To 30 ft. 6.2 in. To 64 ft.		
					Open Hole From ft. To ft.		
					Screen? ☒ Type stainless Make WESCO Diameter Slot/Gauze Length Set 4 in. 12 4 ft. 60 ft. 64 ft.		
					Static Water Level 8 ft. land surface Measure 03/27/2000		
					Pumping Level (below land surface) 25 ft. 1 hrs. Pumping at 25 g.p.m.		
					Wellhead Completion Pitless adapter manufacturer MERRILL Model MCK4100 ☐ Casing Protection ☐ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)		
					Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To bentonite 2 Sacks 0 ft. 30 ft.		
					Nearest Known Source of Contamination <u>75</u> feet <u>West</u> Direction <u>Septic tank/drain field</u> Type Well disinfected upon completion? ☒ Yes ☐ No		
					Pump ☐ Not Installed Date Installed <u>03/28/2000</u> Manufacturer's name GOULD Model Number HP <u>0.5</u> Volt <u>230</u> Length of drop pipe <u>30</u> ft Capacity <u>10</u> g.p. Typ <u>Submersible</u>		
					Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
					Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
					Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date		
					Angled Drill Hole		
					Well Contractor Aqua Well Drilling 04463 EVANS, T Licensee Business Lic. or Reg. No. Name of Driller		