

632158

County Stearns
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 04/12/2000
Update Date 03/11/2005
Received Date

Well Name BEUNING,	Township 126	Range 32	Dir W	Section 12	Subsection CBC	Well Depth 50 ft.	Depth Completed 50 ft.	Date Well Completed 10/30/1999
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid	Other
Address						Use domestic	Status Active	
Contact 334 GOLFVIEW DR ALBANY MN 56307						Well Hydrofractured? Yes ☐ No ☒ From To		
Well RR 1 WINDSOR RD FREEPORT MN 56331						Casing Type Single casing Joint		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☐ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter		
CLAY		0	40	GRAY		5 in. To 45 ft. lbs./ft. 9 in. To 50 ft.		
SAND		40	50					
Open Hole						From	ft.	To ft.
Screen? ☒						Type plastic	Make BIG FOOT	
Diameter						Slot/Gauze	Length	Set
4 in.						20	5 ft.	45 ft. 50 ft.
Static Water Level								
10 ft.						land surface	Measure	10/30/1999
Pumping Level (below land surface)								
15 ft.						2 hrs.	Pumping at	20 g.p.m.
Wellhead Completion								
Pitless adapter manufacturer						Model		
☐ Casing Protection						☐ 12 in. above grade		
☐ At-grade (Environmental Wells and Borings ONLY)								
Grouting Information						Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
Material						Amount	From	To
bentonite							0 ft.	35 ft.
Nearest Known Source of Contamination								
200 feet						South Direction	Septic tank/drain field	Type
Well disinfected upon completion?						☒ Yes ☐ No		
Pump ☐ Not Installed						Date Installed		
Manufacturer's name								
Model Number						HP	Volt	
Length of drop pipe						ft	Capacity	g.p. Typ
Abandoned								
Does property have any not in use and not sealed well(s)?						☐ Yes ☒ No		
Variance								
Was a variance granted from the MDH for this well?						☐ Yes ☒ No		
Miscellaneous								
First Bedrock						Aquifer		
Last Strat						Depth to Bedrock ft		
Located by								
Locate Method								
System UTM - NAD83, Zone 15, Meters						X	Y	
Unique Number Verification						Input Date		
Angled Drill Hole								
Well Contractor								
Albany Wells						73667	ATHEIUS, T.	
Licensee Business						Lic. or Reg. No.	Name of Driller	