

633153

County Stearns
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 12/20/1999
Update Date 03/11/2005
Received Date

Well Name PRATT,	Township 125	Range 30	Dir W	Section 8	Subsection ABD	Well Depth 69 ft.	Depth Completed 67 ft.	Date Well Completed 07/02/1999
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address C/W 36989 PELICAN LAKE RD AVON MN 56310						Use domestic	Status Active	
Stratigraphy Information Geological Material From To (ft.) Color Hardness SAND 0 16 BROWN CLAY 16 54 GRAY SAND 54 67 GRAY CLAY 67 69 GRAY						Well Hydrofractured? Yes ☐ No ☒ From To		
						Casing Type Single casing Joint		
						Drive Shoe? Yes ☐ No ☒ Above/Below		
						Casing Diameter 4 in. To 63 ft. lbs./ft.		
						Hole Diameter 8 in. To 67 ft.		
						Open Hole From ft. To ft.		
						Screen? ☒ Type stainless Make JOHNSON		
						Diameter Slot/Gauze Length Set		
						4 in. 15 4 ft. 63 ft. 67 ft.		
						Static Water Level 4 ft. land surface Measure 07/02/1999		
Pumping Level (below land surface) 67 ft. 1 hrs. Pumping at 45 g.p.m.								
Wellhead Completion Pitless adapter manufacturer MAAS Model 4J1 ☐ Casing Protection ☒ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)								
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To high solids bentonite 2 Sacks 0 ft. 30 ft. cuttings 30 ft. 53 ft.								
Nearest Known Source of Contamination 50 feet West Direction Body of water Type Well disinfected upon completion? ☒ Yes ☐ No								
Pump ☐ Not Installed Date Installed 07/09/1999 Manufacturer's name AERMOTOR Model Number A12B50 HP 0.5 Volt 230 Length of drop pipe 20 ft Capacity 12 g.p. Typ Submersible								
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No								
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No								
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date								
Angled Drill Hole								
Well Contractor Traut M.J. Well Co. 71536 TRAUT, M. Licensee Business Lic. or Reg. No. Name of Driller								