

652842

County Roseau
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 05/21/2001
Update Date 03/11/2005
Received Date

Well Name HULST, RHETT	Township 162	Range 38	Dir W	Section 26	Subsection BAC
Elevation	Elev. Method				
Address					
Contact HEYEN ESTATES SALOL MN 56756					
Well RR SALOL MN 56756					
Stratigraphy Information					
Geological Material		From	To (ft.)	Color	Hardness
CLAY		0	13	BROWN	MEDIUM
CLAY		13	78	GRAY	HARD
FINE SAND		78	125	GRAY	SOFT
CLAY		125	128	GRAY	HARD
Well Depth 128 ft.					
Depth Completed 118 ft.					
Date Well Completed 10/13/2000					
Drill Method Non-specified Rotary					
Drill Fluid Bentonite					
Use domestic					
Status Active					
Well Hydrofractured? Yes ☐ No ☒ From To					
Casing Type Single casing					
Joint Glued					
Drive Shoe? Yes ☐ No ☒ Above/Below					
Casing Diameter Weight Hole Diameter					
4 in. To 114 ft. lbs./ft. 8.5 in. To 20 ft.					
6.2 in. To 128 ft.					
Open Hole From ft. To ft.					
Screen? ☒ Type stainless Make JOHNSON					
Diameter Slot/Gauze Length Set					
4 in. 12 4 ft. 114 ft. 118 ft.					
Static Water Level					
2 ft. land surface Measure 10/13/2000					
Pumping Level (below land surface)					
ft. hrs. Pumping at 75 g.p.m.					
Wellhead Completion					
Pitless adapter manufacturer Model					
☐ Casing Protection ☒ 12 in. above grade					
☐ At-grade (Environmental Wells and Borings ONLY)					
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified					
Material Amount From To					
high solids bentonite 5 Sacks 0 ft. 33 ft.					
Nearest Known Source of Contamination					
feet Direction Type					
Well disinfected upon completion? ☒ Yes ☐ No					
Pump ☒ Not Installed Date Installed					
Manufacturer's name					
Model Number HP Volt					
Length of drop pipe ft Capacity g.p. Typ					
Abandoned					
Does property have any not in use and not sealed well(s)? ☒ Yes ☐ No					
Variance					
Was a variance granted from the MDH for this well? ☐ Yes ☒ No					
Miscellaneous					
First Bedrock Aquifer					
Last Strat Depth to Bedrock ft					
Located by					
Locate Method					
System UTM - NAD83, Zone 15, Meters X Y					
Unique Number Verification Input Date					
Angled Drill Hole					
Well Contractor					
Pelan Well Co. 35396 WYLAND, B.					
Licensee Business Lic. or Reg. No. Name of Driller					