

659333

County Douglas
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 10/19/2001
Update Date 03/11/2005
Received Date

Well Name ANDERSON,	Township 130	Range 38	Dir W	Section 24	Subsection BCD	Well Depth 105 ft.	Depth Completed 105 ft.	Date Well Completed 05/30/2001
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
Contact 15534 FRANCES LA NW MILTONA MN 56354						Well Hydrofractured? Yes ☐ No ☒ From To		
Well HIDDEN VALLEY RD						Casing Type Single casing Joint Unknown		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter		
TOP SOIL		0	1	BLACK	SOFT	4 in. To 101 ft. lbs./ft. 8 in. To 105 ft.		
SAND		1	21	BROWN	SOFT			
FINE SAND		21	78	BROWN	SOFT			
CLAY		78	89	GRAY	MEDIUM			
SAND		89	105	BROWN	SOFT			
						Open Hole From ft. To ft.		
						Screen? ☒ Type stainless Make COOK		
						Diameter Slot/Gauze Length Set		
						4 in. 15 4 ft. 101 ft. 105 ft.		
						Static Water Level		
						35 ft. land surface Measure 05/30/2001		
						Pumping Level (below land surface)		
						105 ft. 2 hrs. Pumping at 100 g.p.m.		
						Wellhead Completion		
						Pitless adapter manufacturer MAASS Model GRADE A		
						☐ Casing Protection ☐ 12 in. above grade		
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
						Material Amount From To		
						high solids bentonite 0 ft. 30 ft.		
						Nearest Known Source of Contamination		
						feet Direction Type		
						Well disinfected upon completion? ☒ Yes ☐ No		
						Pump ☐ Not Installed Date Installed 08/01/2001		
						Manufacturer's name AEROMOTOR		
						Model Number A 12B-50 HP 0.5 Volt 230		
						Length of drop pipe ft Capacity g.p. Typ Submersible		
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
						Miscellaneous		
						First Bedrock Aquifer		
						Last Strat Depth to Bedrock ft		
						Located by		
						Locate Method		
						System UTM - NAD83, Zone 15, Meters X Y		
						Unique Number Verification Input Date		
						Angled Drill Hole		
						Well Contractor		
						Traut S.M. Well Co. 21535 TRAUT, J.		
						Licensee Business Lic. or Reg. No. Name of Driller		