

660663

County Pope
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 10/20/2001
Update Date 10/19/2009
Received Date

Well Name NOHL, ARTHUR					Township 123	Range 40	Dir W	Section 18	Subsection ABD	Well Depth 39 ft.		Depth Completed 39 ft.		Date Well Completed 07/27/2001			
Elevation					Elev. Method					Drill Method Cable Tool		Drill Fluid					
Address										Use irrigation		Status Active					
Well 300TH ST HANCOCK MN 56244										Well Hydrofractured?		Yes ☐ No ☒		From		To	
Contact 859 ATLANTIC AV HANCOCK MN 56244										Casing Type Single casing		Joint					
Stratigraphy Information										Drive Shoe?		Yes ☐ No ☒		Above/Below			
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter		Weight		Hole Diameter							
TOP SANDY LOAM		0	2			12 in. To 27 ft.		lbs./ft.		12 in. To 39 ft.							
RED SAND & GRAVEL		2	10														
MEDIUM TO COARSE		10	39														
										Open Hole		From ft. To ft.					
										Screen? ☒		Type stainless		Make JOHNSON			
										Diameter Slot/Gauze		Length		Set			
										12 in. 100		12 ft.		27 ft. 39 ft.			
										Static Water Level		7 ft. land surface		Measure		07/27/2001	
										Pumping Level (below land surface)		20 ft. 12 hrs. Pumping at		750 g.p.m.			
										Wellhead Completion		Pitless adapter manufacturer		Model			
										☐ Casing Protection		☐ 12 in. above grade					
										☐ At-grade (Environmental Wells and Borings ONLY)							
										Grouting Information		Well Grouted? ☒ Yes ☐ No ☐ Not Specified					
										Material		Amount		From To			
										bentonite				0 ft. 15 ft.			
										pearock				15 ft. 39 ft.			
										Nearest Known Source of Contamination		feet		Direction		Type	
										Well disinfected upon completion?		☒ Yes ☐ No					
										Pump ☐ Not Installed		Date Installed					
										Manufacturer's name							
										Model Number		HP		Volt			
										Length of drop pipe		ft Capacity		g.p. Typ			
										Abandoned		Does property have any not in use and not sealed well(s)?		☐ Yes ☒ No			
										Variance		Was a variance granted from the MDH for this well?		☐ Yes ☒ No			
										Miscellaneous		First Bedrock		Aquifer			
										Last Strat		Depth to Bedrock				ft	
										Located by							
										Locate Method							
										System		UTM - NAD83, Zone 15, Meters		X		Y	
										Unique Number Verification				Input Date			
										Angled Drill Hole							
										Well Contractor		Blue Water Well Co.		73413		KNIGHT, B.	
										Licensee Business		Lic. or Reg. No.		Name of Driller			