

660668

County Stearns
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 12/26/2001
Update Date 03/11/2005
Received Date

Well Name LOPAU, KEVIN	Township 123	Range 35	Dir W	Section 6	Subsection BDD	Well Depth 140 ft.	Depth Completed 140 ft.	Date Well Completed 09/04/2001
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
Contact 11781 8 CR BROOTEN MN 56316						Well Hydrofractured? Yes ☐ No ☒		
Well 25607 BRUTANZA DR BROOTEN MN 56316						From To		
Stratigraphy Information						Casing Type Single casing		
Geological Material						Joint Glued		
TOPSOIL						Drive Shoe? Yes ☐ No ☒		
RED SAND & GRAVEL						Above/Below		
BLUE CLAY						Casing Diameter		
LIMESTONE WITH DRY						Weight		
BLUE CLAY						Hole Diameter		
MED TO COARSE						4 in. To 135 ft. lbs./ft. 4 in. To 140 ft. 8 in. To ft.		
						Open Hole		
						From ft. To ft.		
						Screen? ☒		
						Type plastic		
						Make CERTA-LOK		
						Diameter Slot/Gauze Length Set		
						4 in. 12 5 ft. 135 ft. 140 ft.		
						Static Water Level		
						50 ft. land surface Measure 09/04/2001		
						Pumping Level (below land surface)		
						5 ft. 6 hrs. Pumping at 20 g.p.m.		
						Wellhead Completion		
						Pitless adapter manufacturer Model		
						☐ Casing Protection ☐ 12 in. above grade		
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information		
						Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
						Material Amount From To		
						cuttings 100 ft. 125 ft.		
						bentonite 100 Sacks 125 ft. 140 ft.		
						Nearest Known Source of Contamination		
						feet Direction Type		
						Well disinfected upon completion? ☒ Yes ☐ No		
						Pump ☐ Not Installed Date Installed		
						Manufacturer's name		
						Model Number HP Volt		
						Length of drop pipe ft Capacity g.p. Typ		
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
						Miscellaneous		
						First Bedrock Aquifer		
						Last Strat Depth to Bedrock ft		
						Located by		
						Locate Method		
						System UTM - NAD83, Zone 15, Meters X Y		
						Unique Number Verification Input Date		
						Angled Drill Hole		
						Well Contractor		
						Blue Water Well Co. 73413 KNIGHT, B.		
						Licensee Business Lic. or Reg. No. Name of Driller		