Minnesota Unique Well Number

671630

County Stearns
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH

WELL AND BORING REPORT

Minnesota Statutes Chapter 1031

Entry Date 07/09/2002
Update Date 03/11/2005
Received Date

Well Name	Township	Range	Dir	Section	Subsection
LINNEMAN, SKIP	124	30	W	9	DDB

Elevation **Elev. Method**

Address

Contact BOX 395 COLD SPRING MN 56320
Well 16434 LAUREL RD ROTHSAY MN 56579

Stratigraphy Information

Geological Material	From	To (ft.)	Color	Hardness
SAND	0	14	GRAY	SOFT
CLAY	14	17	GRAY	MEDIUM
SAND	17	25	GRAY	SOFT

Remarks

Well Depth 25 ft. **Depth Completed** 25 ft. **Date Well Completed** 12/28/2001

Drill Method Non-specified Rotary **Drill Fluid** Bentonite

Use domestic **Status** Active

Well Hydrofractured? **Yes** ☐ **No** ☒ **From** **To**

Casing Type Single casing **Joint**
Drive Shoe? **Yes** ☐ **No** ☒ **Above/Below**

Casing Diameter	Weight	Hole Diameter
4 in. To 21 ft.	lbs./ft.	8 in. To 25 ft.

Open Hole From ft. To ft.

Screen? ☒ **Type** plastic **Make** JOHNSON

Diameter	Slot/Gauze	Length	Set
4 in.	18	4 ft.	21 ft. 25 ft.

Static Water Level
1 ft. land surface Measure 12/28/2001

Pumping Level (below land surface)
25 ft. 1 hrs. Pumping at 45 g.p.m.

Wellhead Completion
Pitless adapter manufacturer MAASS Model 4J1
☐ Casing Protection ☐ 12 in. above grade
☐ At-grade (Environmental Wells and Borings ONLY)

Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified

Material	Amount	From	To
high solids bentonite	2	0 ft.	18 ft.

Nearest Known Source of Contamination
75 feet East Direction Septic tank/drain field Type
Well disinfected upon completion? ☒ Yes ☐ No

Pump ☐ Not Installed Date Installed 04/28/2002
Manufacturer's name AERMOTOR
Model Number TE12-50 HP 0.5 Volt 230
Length of drop pipe 10 ft Capacity 12 g.p. Typ Submersible

Abandoned
Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No

Variance
Was a variance granted from the MDH for this well? ☐ Yes ☒ No

Miscellaneous
First Bedrock Aquifer
Last Strat Depth to Bedrock ft
Located by
Locate Method
System UTM - NAD83, Zone 15, Meters X Y
Unique Number Verification Input Date

Angled Drill Hole

Well Contractor
Traut M.J. Well Co. 71536 TRAUT, M.
Licensee Business Lic. or Reg. No. Name of Driller