

692999

County Isanti
Quad Cambridge
Quad ID 152C

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 11/15/2005
Update Date 06/03/2015
Received Date 03/24/2006

Well Name CARIVEAU,					Township 36	Range 23	Dir W	Section 36	Subsection ABCCBA	Well Depth 146 ft.					Depth Completed 146 ft.					Date Well Completed 08/03/2005									
Elevation 948 ft.					Elev. Method 7.5 minute topographic map (+/- 5 feet)					Drill Method Cable Tool															Drill Fluid Water				
Address C/W 33144 MARMON ST NE CAMBRIDGE MN 55008										Use domestic															Status Active				
Stratigraphy Information Geological Material From To (ft.) Color Hardness CLAY 0 25 YELLOW HARD CLAY 25 50 GRAY HARD SAND & CLAY 50 70 RED/BRN MEDIUM SANDSTONE 70 97 TAN MEDIUM SANDSTONE & SHALE 97 130 GREEN MEDIUM SANDSTONE, WATER 130 146 WHITE										Well Hydrofractured? Yes ☐ No ☐ From To																			
										Casing Type Single casing Joint Threaded																			
										Drive Shoe? Yes ☒ No ☐ Above/Below																			
										Casing Diameter Weight 4 in. To 140 ft. 11 lbs./ft.																			
										Open Hole From ft. To ft.																			
										Screen? ☒ Type stainless Make JOHNSON Diameter Slot/Gauze Length Set 2 in. 12 5 ft. 141 ft. 146 ft.																			
										Static Water Level 8 ft. land surface Measure 08/03/2005																			
										Pumping Level (below land surface) 30 ft. 2 hrs. Pumping at 25 g.p.m.																			
										Wellhead Completion Pitless adapter manufacturer SNAPPY Model ☐ Casing Protection ☐ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)																			
										Grouting Information Well Grouted? ☐ Yes ☒ No ☐ Not Specified																			
Remarks VARIANCE TN# 3479.										Nearest Known Source of Contamination 55 feet East Direction Septic tank/drain field Type Well disinfected upon completion? ☐ Yes ☐ No																			
										Pump ☐ Not Installed Date Installed 08/02/2005 Manufacturer's name AERMOTOR Model Number T12-50 HP 0.5 Volt 115 Length of drop pipe 40 ft Capacity 12 g.p. Typ Submersible																			
										Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☐ No																			
										Variance Was a variance granted from the MDH for this well? ☒ Yes ☐ No																			
										Miscellaneous First Bedrock Tunnel City Group Aquifer Wonewoc Last Strat Wonewoc Sandstone Depth to Bedrock 70 ft Located by Minnesota Department of Health Locate Method GPS SA Off (averaged) (15 meters) System UTM - NAD83, Zone 15, Meters X 488168 Y 5046248 Unique Number Verification Input Date 10/18/2005																			
										Angled Drill Hole																			
										Well Contractor Lindsay Well Co. 30385 LINDSAY, R. Licensee Business Lic. or Reg. No. Name of Driller																			

Minnesota Well Index Report

692999

Printed on 08/13/2026
HE-01205-15