

710579

County Crow Wing
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 07/12/2006
Received Date 01/06/2005

Well Name JENSEN, GARY Elevation Address Well 15065 THOMPSON RD MN Stratigraphy Information <table><tr><td>Geological Material</td><td>From</td><td>To (ft.)</td><td>Color</td><td>Hardness</td></tr><tr><td>TOPSOIL</td><td>0</td><td>2</td><td>BLACK</td><td>SOFT</td></tr><tr><td>CLAY</td><td>2</td><td>22</td><td>BROWN</td><td>MEDIUM</td></tr><tr><td>CLAY</td><td>22</td><td>40</td><td>GRAY</td><td>MEDIUM</td></tr><tr><td>SAND & CLAY</td><td>40</td><td>81</td><td>BROWN</td><td>MEDIUM</td></tr><tr><td>SAND & CLAY</td><td>81</td><td>109</td><td>GRAY</td><td>MEDIUM</td></tr><tr><td>SAND</td><td>109</td><td>122</td><td>BROWN</td><td>MEDIUM</td></tr></table>	Geological Material	From	To (ft.)	Color	Hardness	TOPSOIL	0	2	BLACK	SOFT	CLAY	2	22	BROWN	MEDIUM	CLAY	22	40	GRAY	MEDIUM	SAND & CLAY	40	81	BROWN	MEDIUM	SAND & CLAY	81	109	GRAY	MEDIUM	SAND	109	122	BROWN	MEDIUM	Well Depth 122 ft. Drill Method Non-specified Rotary Use domestic Well Hydrofractured? Yes ☐ No ☒ Casing Type Single casing Drive Shoe? Yes ☐ No ☒ Casing Diameter 4 in. To 114 ft. Weight lbs./ft. Hole Diameter 8 in. To 122 ft. Open Hole From ft. To ft. Screen? ☒ Slot/Gauze Diameter 4 in. Length 12 Type stainless Make JOHNSON Set 114 ft. Length 8 ft. Static Water Level 38 ft. land surface Measure 09/09/2004 Pumping Level (below land surface) 121 ft. 1 hrs. Pumping at 25 g.p.m. Wellhead Completion Pitless adapter manufacturer Model ☐ Casing Protection ☐ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY) Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material high solids bentonite Amount 3 Sacks From ft. To ft. 30 ft. Nearest Known Source of Contamination feet Direction Type Well disinfected upon completion? ☒ Yes ☐ No Pump ☐ Not Installed Date Installed Manufacturer's name Model Number HP Volt Length of drop pipe ft Capacity g.p. Typ Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date Angled Drill Hole Well Contractor Traut S.M. Well Co. 21535 CHRIS Licensee Business Lic. or Reg. No. Name of Driller
Geological Material	From	To (ft.)	Color	Hardness																																
TOPSOIL	0	2	BLACK	SOFT																																
CLAY	2	22	BROWN	MEDIUM																																
CLAY	22	40	GRAY	MEDIUM																																
SAND & CLAY	40	81	BROWN	MEDIUM																																
SAND & CLAY	81	109	GRAY	MEDIUM																																
SAND	109	122	BROWN	MEDIUM																																
Remarks																																				