

723418

County Wilkin
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date11/02/2007
Update Date06/23/2009
Received Date02/02/2007

Well Name DREWLOW,	Township 134	Range 48	Dir W	Section 13	Subsection DCD	Well Depth 380 ft.	Depth Completed 380 ft.	Date Well Completed 08/10/2006							
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid	Other							
Address C/W1578 250TH ST KENT MN 56553						Use domestic	Status Active								
						Well Hydrofractured?			Yes ☐	No ☒	From	To			
						Casing Type			Step down		Joint				
Stratigraphy Information Geological MaterialFromTo (ft.)ColorHardness TOPSOIL04BLACKSOFT CLAY445YELLOWSOFT CLAY4590BLUESOFT CLAY90300BLUESOFT CLAY300365DARKHARD SAND365380WHITEHARD						Drive Shoe?	Yes ☐	No ☒	Above/Below						
						Casing Diameter		Weight		Hole Diameter					
						5 in. To		365 ft. lbs./ft.		9 in. To 365 ft.					
						Open Hole						From	ft.	To	ft.
						Screen?	☒	Type	stainless		Make	JOHNSON			
						Diameter	Slot/Gauze	Length	Set						
						2 in.	12	15 ft.	365 ft.		380 ft.				
						Static Water Level									
						6 ft.		land surface		Measure		08/10/2006			
						Pumping Level (below land surface)									
120 ft.		2 hrs.		Pumping at		10 g.p.m.									
Wellhead Completion															
Pitless adapter manufacturer						MONITOR		Model							
☐ Casing Protection						☒ 12 in. above grade									
☐ At-grade (Environmental Wells and Borings ONLY)															
Grouting Information						Well Grouted?									
						☒ Yes		☐ No	☐ Not Specified						
Material						Amount		From	To						
bentonite						7 Sacks		0 ft.	100 ft.						
neat cement						20 Sacks		100 ft.	365 ft.						
Nearest Known Source of Contamination															
200 feet						Southwes		Direction	Septic tank/drain field	Type					
Well disinfected upon completion?						☒ Yes		☐ No							
Pump						☐ Not Installed		Date Installed	08/10/2006						
Manufacturer's name						GOULDS									
Model Number						10GS		HP	0.75	Volt	220				
Length of drop pipe						200 ft		Capacity	10 g.p.	Typ	Submersible				
Abandoned															
Does property have any not in use and not sealed well(s)?						☐ Yes		☒ No							
Variance															
Was a variance granted from the MDH for this well?						☐ Yes		☒ No							
Miscellaneous															
First Bedrock						Aquifer									
Last Strat						Depth to Bedrock		ft							
Located by															
Locate Method															
System						UTM - NAD83, Zone 15, Meters		X	Y						
Unique Number Verification								Input Date							
Angled Drill Hole															
Well Contractor															
Wieber Well Drilling						2110		WIEBER, J.							
Licensee Business						Lic. or Reg. No.		Name of Driller							