

737810

County Hubbard
Quad Mantrap
Quad ID 278C

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 10/26/2007
Update Date 01/08/2014
Received Date 05/02/2007

Well Name THOMAS, BOB	Township 141	Range 34	Dir W	Section 22	Subsection DCBACB	Well Depth 75 ft.	Depth Completed 75 ft.	Date Well Completed 08/25/2006
Elevation 1481	Elev. Method 7.5 minute topographic map (+/- 5 feet)				Drill Method Non-specified Rotary	Drill Fluid Bentonite		
Address Well 18963 40 CR PARK RAPIDS MN 56470						Use domestic	Status Active	
Stratigraphy Information Geological Material From To (ft.) Color Hardness SAND & GRAVEL 0 75 BROWN SFT-MED						Well Hydrofractured? Yes ☐ No ☒ From To		
						Casing Type Single casing Joint		
						Drive Shoe? Yes ☐ No ☒ Above/Below		
						Casing Diameter Weight Hole Diameter		
						4 in. To 70 ft. lbs./ft. 8 in. To 30 ft.		
						6 in. To 75 ft.		
						Open Hole From ft. To ft.		
						Screen? ☒ Type stainless Make JOHNSON		
						Diameter Slot/Gauze Length Set		
						2 in. 15 5 ft. 70 ft. 75 ft.		
Static Water Level 50 ft. land surface Measure 08/25/2006								
Pumping Level (below land surface) 55 ft. 1 hrs. Pumping at 15 g.p.m.								
Wellhead Completion Pitless adapter manufacturer MONITOR Model SNAPPY ☐ Casing Protection ☐ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)								
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To 3 Sacks 10 ft. 40 ft.								
Nearest Known Source of Contamination 75 feet Northwes Direction Septic tank/drain field Type Well disinfected upon completion? ☐ Yes ☐ No								
Pump ☐ Not Installed Date Installed 08/25/2006 Manufacturer's name MCDONALD Model Number 220S0K3 HP 0.5 Volt 230 Length of drop pipe 60 ft Capacity 10 g.p. Typ Submersible								
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No								
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No								
Miscellaneous First Bedrock Aquifer Quat. Water Last Strat sand +larger-brown Depth to Bedrock ft Located by Minnesota Department of Health Locate Method Digitization (Screen) - Map (1:24,000) (15 meters or System UTM - NAD83, Zone 15, Meters X 350340 Y 5208180 Unique Number Verification Info/GPS from data Input Date 11/30/2006								
Angled Drill Hole								
Well Contractor Traut Wells - Park Rapids 1306 HENSEL, J. Licensee Business Lic. or Reg. No. Name of Driller								