

758534

County Anoka
Quad Typo Lake
Quad ID 135A

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 02/15/2008
Update Date 08/18/2014
Received Date

Well Name VITCAK, JIM	Township 34	Range 22	Dir W	Section 29	Subsection ABDCAB	Well Depth 126 ft.	Depth Completed 126 ft.	Date Well Completed 10/17/2007
Elevation 908 ft.	Elev. Method 7.5 minute topographic map (+/- 5 feet)					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address Well 24330 VIRGO ST NE STACY MN 55079						Use domestic	Status Active	
Stratigraphy Information Geological Material From To (ft.) Color Hardness SAND 0 40 CLAY & ROCK 40 90 ROCK 90 105 MEDIUM ROCK 105 126 HARD						Well Hydrofractured? Yes ☐ No ☒ From To		
						Casing Type Single casing Joint Threaded		
						Drive Shoe? Yes ☒ No ☐ Above/Below		
						Casing Diameter Weight Hole Diameter 4 in. To 105 ft. 11 lbs./ft. 8 in. To 20 ft. 6.2 in. To 105 ft.		
						Open Hole From 105 ft. To 126 ft.		
						Screen? ☐ Type Make		
						Static Water Level 20 ft. land surface Measure 10/17/2007		
						Pumping Level (below land surface) 90 ft. 1 hrs. Pumping at 20 g.p.m.		
						Wellhead Completion Pitless adapter manufacturer SNAPPY Model 8PL4IU ☐ Casing Protection ☒ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To high solids bentonite 3 Sacks ft. 30 ft.		
						Nearest Known Source of Contamination 55 feet West Direction Septic tank/drain field Type Well disinfected upon completion? ☒ Yes ☐ No		
						Pump ☒ Not Installed Date Installed Manufacturer's name Model Number HP Volt Length of drop pipe ft Capacity g.p. Typ		
						Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
						Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
						Miscellaneous First Bedrock St.Lawrence-Tunnel City Aquifer Tunnel City Last Strat Tunnel City Group Depth to Bedrock 90 ft Located by Minnesota Department of Health Locate Method GPS SA Off (averaged) (15 meters) System UTM - NAD83, Zone 15, Meters X 491473 Y 5028593 Unique Number Verification Info/GPS from data Input Date 10/22/2007		
						Angled Drill Hole		
						Well Contractor Lauren Mccullough Well 1427 RHOADES, H. Licensee Business Lic. or Reg. No. Name of Driller		