

775397

County Stearns
Quad Sauk
Quad ID 159B

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 08/17/2010
Update Date 03/13/2024
Received Date 04/18/2011

Well Name SAUK CENTRE, 126					Township 34	Range W 10	Dir Section CDDBAA	Subsection	Well Depth 72 ft.	Depth Completed 72 ft.	Date Well Completed 04/13/2011																				
Elevation 1232					Elev. Method Calc from DEM (USGS 7.5 min or equiv.)		Drill Method			Drill Fluid																					
Address Well N/A 6TH ST SAUK CENTRE MN 56378 Contact 320 OAK ST S SAUK CENTRE MN 56378									Use irrigation Status Sealed																						
Stratigraphy Information									Well Hydrofractured? Yes ☐ No ☐ From To																						
<table><tr><td>Geological Material</td><td>From</td><td>To (ft.)</td><td>Color</td><td>Hardness</td></tr><tr><td>COARSE GRAVEL</td><td>0</td><td>41</td><td>BROWN</td><td></td></tr><tr><td>CLAY</td><td>41</td><td>63</td><td>BLUE</td><td>MEDIUM</td></tr><tr><td>SAND</td><td>63</td><td>72</td><td>VARIED</td><td>MEDIUM</td></tr></table>									Geological Material	From	To (ft.)	Color	Hardness	COARSE GRAVEL	0	41	BROWN		CLAY	41	63	BLUE	MEDIUM	SAND	63	72	VARIED	MEDIUM	Casing Type Single casing Joint Unknown		
Geological Material	From	To (ft.)	Color	Hardness																											
COARSE GRAVEL	0	41	BROWN																												
CLAY	41	63	BLUE	MEDIUM																											
SAND	63	72	VARIED	MEDIUM																											
									Drive Shoe? Yes ☐ No ☐ Above/Below																						
									Casing Diameter Weight Hole Diameter 5 in. To 64 ft. lbs./ft. 64 in. To 72 ft.																						
									Open Hole From ft. To ft.																						
									Screen? ☐ Type Make																						
									Static Water Level 15 ft. null Measure 05/20/2010																						
									Pumping Level (below land surface)																						
									Wellhead Completion Pitless adapter manufacturer Model ☐ Casing Protection ☐ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)																						
									Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To bentonite ft. 72 ft.																						
									Nearest Known Source of Contamination feet Direction Type Well disinfected upon completion? ☐ Yes ☐ No																						
									Pump ☐ Not Installed Date Installed Manufacturer's name Model Number HP Volt Length of drop pipe ft Capacity g.p. Typ																						
									Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No																						
									Variance Was a variance granted from the MDH for this well? ☐ Yes ☐ No																						
									Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Minnesota Department of Health Locate Method GPS SA Off (averaged) (15 meters) System UTM - NAD83, Zone 15, Meters X 348699 Y 5066161 Unique Number Verification Info/GPS from data Input Date 05/21/2010																						
									Angled Drill Hole																						
									Well Contractor Mancl Maher Well Drilling, 1457 MANTHEI, B. Licensee Business Lic. or Reg. No. Name of Driller																						