

780746

County Wilkin
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date

Update Date05/28/2025

Received Date05/04/2021

Well Name	Township	Range	Dir	Section	Subsection	Well Depth	Depth Completed	Date Well Completed				
GROTLUSOHEN, 134		47	W	7	DCD	290 ft.	290 ft.	04/24/2020				
Elevation	Elev. Method					Drill Method	Non-specified Rotary	Drill Fluid	Bentonite			
Address						Use	domestic	Status	Active			
						Well Hydrofractured?	Yes	☐	No	☒	From	To
						Casing Type	Step down	Joint				
Stratigraphy Information						Drive Shoe?	Yes	☐	No	☒	Above/Below	
						Casing Diameter	Weight	Hole Diameter				
						Geological Material	From	To (ft.)	Color	Hardness	5 in. To	198 ft. 278 lbs./ft.
TOP SOIL	0	4	BLACK	SOFT	5 in. To	6 ft. 198 lbs./ft.	8.5 in. To	278 ft.				
CLAY	4	30	YELLOW	SOFT								
CLAY	30	90	BLUE	MEDIUM								
CLAY	90	200	BLUE	HARD								
CLAY	200	278	BLUE	V.HARD								
SAND	278	290	WHITE	HARD								
						Open Hole	From	ft.	To	ft.		
						Screen?	☒	Type	stainless	Make	JOHNSON	
						Diameter	Slot/Gauze	Length	Set			
						2 in.	10	12 ft.	278 ft.	290 ft.		
						Static Water Level						
						28 ft.	land surface	Measure	04/24/2020			
						Pumping Level (below land surface)						
						70 ft.	1 hrs.	Pumping at	25 g.p.m.			
						Wellhead Completion						
						Pitless adapter manufacturer	QUICKCONNECT	Model	5X6			
						☐ Casing Protection	☒ 12 in. above grade					
						☐ At-grade (Environmental Wells and Borings ONLY)						
						Grouting Information	Well Grouted?	☒ Yes	☐ No	☐ Not Specified		
						Material	Amount	From	To			
						neat cement	12 Sacks	6 ft.	278 ft.			
						Nearest Known Source of Contamination						
						100 feet	Northwes	Direction	Septic tank/drain field	Type		
						Well disinfected upon completion?	☒ Yes	☐ No				
						Pump	☐ Not Installed	Date Installed	04/24/2020			
						Manufacturer's name	GOULDS					
						Model Number	10C07	HP	0.75	Volt	240	
						Length of drop pipe	100 ft	Capacity	15 g.p.	Typ	Submersible	
						Abandoned						
						Does property have any not in use and not sealed well(s)?	☒ Yes	☐ No				
						Variance						
						Was a variance granted from the MDH for this well?	☐ Yes	☒ No				
						Miscellaneous						
						First Bedrock	Aquifer					
						Last Strat	Depth to Bedrock					ft
						Located by						
						Locate Method						
						System	UTM - NAD83, Zone 15, Meters	X	Y			
						Unique Number Verification	Input Date					
						Angled Drill Hole						
						Well Contractor						
						Wieber Well Drilling	2110	WIEBER, D				
						Licensee Business	Lic. or Reg. No.	Name of Driller				