

785399

County Roseau
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 03/02/2015
Update Date 03/02/2015
Received Date 01/20/2015

Well Name BESSLER,	Township 160	Range 38	Dir Section W 25	Subsection CBC	Well Depth 122 ft.	Depth Completed 122 ft.	Date Well Completed 10/03/2013
Elevation	Elev. Method				Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address					Use domestic	Status Active	
Contact 6922 LAKE SHORE DR WILLIAMS MN 56686					Well Hydrofractured? Yes ☐ No ☒ From To		
Stratigraphy Information					Casing Type Single casing Joint Glued		
					Drive Shoe? Yes ☐ No ☐ Above/Below		
Geological Material					Casing Diameter Weight Hole Diameter		
FINE SAND					4 in. To 118 ft. 1.9 lbs./ft. 6.7 in. To 122 ft.		
CLAY							
CLAY							
CLAY/FINE SAND							
GRAVEL							
					Open Hole From ft. To ft.		
					Screen? ☒ Type stainless Make JOHNSON		
					Diameter Slot/Gauze Length Set		
					4 in. 12 4 ft. 118 ft. 122 ft.		
					Static Water Level		
					Pumping Level (below land surface)		
					ft. 2 hrs. Pumping at 60 g.p.m.		
					Wellhead Completion		
					Pitless adapter manufacturer Model		
					☐ Casing Protection ☒ 12 in. above grade		
					☐ At-grade (Environmental Wells and Borings ONLY)		
					Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
					Material Amount From To		
					other 0.25 Cubic yards 80 ft. 110 ft.		
					pearock 7 Sacks 110 ft. 122 ft.		
					bentonite 6 Sacks ft. 80 ft.		
					Nearest Known Source of Contamination		
					300 feet Northwes Direction Septic tank/drain field Type		
					Well disinfected upon completion? ☒ Yes ☐ No		
					Pump ☒ Not Installed Date Installed		
					Manufacturer's name		
					Model Number HP Volt		
					Length of drop pipe ft Capacity g.p. Typ		
					Abandoned		
					Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
					Variance		
					Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
					Miscellaneous		
					First Bedrock Aquifer		
					Last Strat Depth to Bedrock ft		
					Located by		
					Locate Method		
					System UTM - NAD83, Zone 15, Meters X Y		
					Unique Number Verification Input Date		
					Angled Drill Hole		
					Well Contractor		
					Pelan Construction And Well 1756 GUNDERSON, B.		
					Licensee Business Lic. or Reg. No. Name of Driller		