

788455

County Mahnomen
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date01/10/2013
Update Date01/11/2013
Received Date07/30/2012

Well Name CURRAN, ADAM	Township 146	Range 39	Dir W	Section 18	Subsection DAA
Elevation	Elev. Method				
Address Well2892 125TH ST LENGBY MN 56651					
Stratigraphy Information					
Geological Material	From	To (ft.)	Color	Hardness	
TOPSOIL	0	1	BLACK	SOFT	
CLAY	1	29	YELLOW	MEDIUM	
CLAY	29	114	GRAY	MEDIUM	
SAND	114	125	GRAY	SOFT	
Well Depth125 ft. Depth Completed125 ft. Date Well Completed05/31/2012					
Drill MethodNon-specified Rotary Drill FluidOther					
Use domestic StatusActive					
Well Hydrofractured? Yes ☐ No ☒ From To					
Casing TypeSingle casing Joint					
Drive Shoe? Yes ☐ No ☒ Above/Below					
Casing DiameterWeightHole Diameter					
4 in. To117 ft. lbs./ft. 6.7 in. To125 ft.					
Open HoleFromft. Toft.					
Screen? ☒ Typestainless MakeJOHNSON					
DiameterSlot/GauzeLengthSet					
2 in.158 ft. 117 ft.125 ft.					
Static Water Level					
38 ft. land surface Measure 05/31/2012					
Pumping Level (below land surface)					
125 ft. 2 hrs. Pumping at 40 g.p.m.					
Wellhead Completion					
Pitless adapter manufacturerModel					
☐ Casing Protection ☒ 12 in. above grade					
☐ At-grade (Environmental Wells and Borings ONLY)					
Grouting InformationWell Grouted? ☒ Yes ☐ No ☐ Not Specified					
MaterialAmountFromTo					
bentonite3 Sacks0 ft.50 ft.					
Nearest Known Source of Contamination					
50 feet NortheasDirection Septic tank/drain fieldType					
Well disinfected upon completion? ☒ Yes ☐ No					
Pump ☐ Not Installed Date Installed05/31/2012					
Manufacturer's nameSCHAEFER					
Model NumberHP0.5 Volt23					
Length of drop pipe60 ft Capacity10 g.p. TypSubmersible					
Abandoned					
Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No					
Variance					
Was a variance granted from the MDH for this well? ☐ Yes ☒ No					
Miscellaneous					
First BedrockAquifer					
Last StratDepth to Bedrockft					
Located by					
Locate Method					
SystemUTM - NAD83, Zone 15, Meters X Y					
Unique Number Verification Input Date					
Angled Drill Hole					
Well Contractor					
Brovold Wells2149 AFFELDT, M.					
Licensee Business Lic. or Reg. No. Name of Driller					