

793961

County Anoka
Quad Coon Lake
Quad ID 135C

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 02/26/2013
Update Date 05/19/2015
Received Date 12/24/2012

Well Name ACCENT HOMES 32					Township 23	Range W 1	Dir ACDBDC	Subsection	
Elevation 909 ft.					Elev. Method Calc from NED (Natl.Elev.Dataset-30m)				
Address									
Well 17715 NATIONAL ST NE HAM LAKE MN 55304									
Stratigraphy Information									
Geological Material		From	To (ft.)	Color	Hardness				
SAND		0	27	BROWN	SOFT				
CLAY/SAND		27	66	BROWN	MEDIUM				
SAND		66	82	BROWN	SOFT				
Well Depth 82 ft.									
Depth Completed 82 ft.									
Date Well Completed 12/13/2012									
Drill Method Non-specified Rotary									
Drill Fluid Bentonite									
Use domestic									
Status Active									
Well Hydrofractured? Yes ☐ No ☒ From To									
Casing Type Single casing									
Joint									
Drive Shoe? Yes ☐ No ☒ Above/Below									
Casing Diameter 4 in. To 72 ft.									
Weight lbs./ft.									
Hole Diameter 8 in. To 82 ft.									
Open Hole From ft. To ft.									
Screen? ☒ Type plastic									
Make BIGFOOT									
Diameter Slot/Gauze Length Set									
4 in. 15 10 ft. 72 ft. 82 ft.									
Static Water Level									
18 ft. land surface Measure 12/13/2012									
Pumping Level (below land surface)									
70 ft. 3 hrs. Pumping at 30 g.p.m.									
Wellhead Completion									
Pitless adapter manufacturer MAASS Model JC-4									
☐ Casing Protection ☒ 12 in. above grade									
☐ At-grade (Environmental Wells and Borings ONLY)									
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified									
Material Amount From To									
other 9 Sacks 0 ft. 60 ft.									
Nearest Known Source of Contamination									
50 feet South Direction Sewer Type									
Well disinfected upon completion? ☒ Yes ☐ No									
Pump ☐ Not Installed Date Installed 12/13/2012									
Manufacturer's name GRUNDFOS									
Model Number HP 1 Volt 230									
Length of drop pipe 40 ft Capacity 20 g.p. Typ Submersible									
Abandoned									
Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No									
Variance									
Was a variance granted from the MDH for this well? ☐ Yes ☒ No									
Miscellaneous									
First Bedrock Aquifer									
Last Strat Depth to Bedrock ft									
Located by Minnesota Department of Health									
Locate Method GPS SA Off (averaged) (15 meters)									
System UTM - NAD83, Zone 15, Meters X 488308 Y 5015327									
Unique Number Verification Info/GPS from data Input Date 11/21/2012									
Angled Drill Hole									
Well Contractor									
A Ruppert Well, Inc. 1572 RUPPERT, C.									
Licensee Business Lic. or Reg. No. Name of Driller									