

Quad ID

Entry Date	06/16/2025
Update Date	06/16/2025
Received Date	07/28/2014

Well Name SINCLAIR,	Township 132	Range 39	Dir W	Section 4	Subsection ADC	Well Depth 66 ft.	Depth Completed 66 ft.	Date Well Completed 07/07/2014
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Qwik gel	
Address						Use domestic	Status Active	
Well 43357 JOHN FOX DR CLITHERALL MN 56524						Well Hydrofractured? Yes ☐ No ☐	From To	
Contact CLITHERALL MN 56524						Casing Type Single casing	Joint	
Stratigraphy Information						Drive Shoe? Yes ☐ No ☐	Above/Below	
Geological Material						From	To (ft.)	Color
TOP SOIL						0	2	
SAND						2	40	BROWN
SAND						40	45	BROWN
CLAY						45	55	YELLOW
CLAY						55	59	BLUE
SAND						59	66	
Open Hole						From	ft.	To
Screen? ☒						Type stainless	Make JOHNSON	
Diameter						Slot/Gauze	Length	Set
5 in.						20	5 ft.	61 ft.
Static Water Level						43 ft.	land surface	Measure
								07/07/2014
Pumping Level (below land surface)						ft.	hrs.	Pumping at
							20	g.p.m.
Wellhead Completion						Pitless adapter manufacturer	Model	
☐ Casing Protection						☒ 12 in. above grade		
☐ At-grade (Environmental Wells and Borings ONLY)								
Grouting Information						Well Grouted? ☒	Yes ☐ No ☐	Not Specified
Material						Amount	From	To
bentonite							ft. 50	ft.
Nearest Known Source of Contamination						110 feet	North Direction	Sewer Type
Well disinfected upon completion?						☒ Yes	☐ No	
Pump ☐ Not Installed						Date Installed		
Manufacturer's name						GOULDS		
Model Number						HP	0.5	Volt
Length of drop pipe						56 ft	Capacity	10 g.p.
Abandoned						Does property have any not in use and not sealed well(s)?	☐ Yes	☒ No
Variance						Was a variance granted from the MDH for this well?	☐ Yes	☒ No
Miscellaneous						First Bedrock	Aquifer	
Last Strat						Depth to Bedrock		ft
Located by								
Locate Method								
System						UTM - NAD83, Zone 15, Meters	X	Y
Unique Number Verification							Input Date	
Angled Drill Hole								
Well Contractor						Waskosky Well Drilling	1581	DAVE, KYLE
Licensee Business						Lic. or Reg. No.		Name of Driller
Remarks						HARDNESS OF 40-45' IS "TAKES WATER"		
Minnesota Well Index Report						806529		
						Printed on 08/13/2026		
						HE-01205-15		