

817859

County Washington
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 06/18/2018
Update Date 12/27/2018
Received Date 12/22/2017

Well Name DIVINE CUSTOM 28	Township 20	Range W 18	Dir Section CBA	Subsection
Elevation	Elev. Method			
Address				
Contact 397 EAGLE BLUFF CT HUDOSN WI 54016				
Well 2698 MEADOW VISTA WA AFTON MN 55001				
Stratigraphy Information				
Geological Material	From	To (ft.)	Color	Hardness
CLAY	0	20	BROWN	SOFT
LIMESTONE	20	370	BRN/YEL	HARD
SANDSTONE	370	420	BROWN	MEDIUM
Well Depth 420 ft.				
Depth Completed 420 ft.				
Date Well Completed 12/07/2017				
Drill Method Non-specified Rotary				
Drill Fluid Foam				
Use domestic				
Status Active				
Well Hydrofractured? Yes ☐ No ☒				
From To				
Casing Type Single casing				
Joint Welded				
Drive Shoe? Yes ☒ No ☐				
Above/Below				
Casing Diameter Weight Hole Diameter				
8 in. To 20 ft. lbs./ft. 8 in. To 390 ft.				
4 in. To 390 ft. lbs./ft. 4 in. To 420 ft.				
0 in. To ft.				
Open Hole From 390 ft. To 420 ft.				
Screen? ☐ Type Make				
Static Water Level				
190 ft. null Measure 12/07/2017				
Pumping Level (below land surface)				
200 ft. 2 hrs. Pumping at 20 g.p.m.				
Wellhead Completion				
Pitless adapter manufacturer BAKER Model 531				
☐ Casing Protection ☒ 12 in. above grade				
☐ At-grade (Environmental Wells and Borings ONLY)				
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified				
Material Amount From To				
pearock 10 Cubic yards 100 ft. 280 ft.				
neat cement 12 Cubic yards ft. 390 ft.				
Nearest Known Source of Contamination				
90 feet West Direction Septic tank/drain field Type				
Well disinfected upon completion? ☒ Yes ☐ No				
Pump ☒ Not Installed Date Installed				
Manufacturer's name				
Model Number HP Volt				
Length of drop pipe ft Capacity g.p. Typ				
Abandoned				
Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No				
Variance				
Was a variance granted from the MDH for this well? ☐ Yes ☒ No				
Miscellaneous				
First Bedrock Aquifer				
Last Strat Depth to Bedrock ft				
Located by				
Locate Method				
System UTM - NAD83, Zone 15, Meters X Y				
Unique Number Verification Input Date				
Angled Drill Hole				
Well Contractor				
Tim Butterfield Drilling, Inc. 2660 MAGNUSON, D.				
Licensee Business Lic. or Reg. No. Name of Driller				