

817860

County Washington
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 06/18/2018
Update Date 09/13/2018
Received Date 02/12/2018

Well Name DIVINE CUSTOM 27					Township 20		Range W 3		Dir Section CCC		Well Depth 360 ft.			Depth Completed 360 ft.			Date Well Completed 01/24/2018												
Elevation					Elev. Method					Drill Method Non-specified Rotary			Drill Fluid Foam																
Address															Use domestic			Status Active											
Well 15054 70TH ST S HASTINGS MN 55033															Well Hydrofractured?			Yes ☐ No ☒			From To								
Contact 397 EAGLE BLUFF CT HUDSON WI 54016															Casing Type Single casing			Joint Welded											
Stratigraphy Information															Drive Shoe?			Yes ☒ No ☐			Above/Below								
Geological Material					From		To (ft.)		Color		Hardness		Casing Diameter			Weight			Hole Diameter										
SAND/CLAY					0		17		BROWN		MEDIUM		4 in. To 260 ft.			lbs./ft.			8 in. To 260 ft.										
LIMESTON					17		90		YELLOW		HARD		8 in. To 17 ft.			lbs./ft.			4 in. To 360 ft.										
SANDROCK					90		225		YELLOW		MEDIUM																		
SANDROCK					225		300		GRAY		MEDIUM																		
SANDROCK					300		360		GREEN		MEDIUM																		
															Open Hole			From 260 ft.			To 360 ft.								
															Screen? ☐			Type			Make								
															Static Water Level			250 ft.			top of casing			Measure 01/24/2018					
															Pumping Level (below land surface)														
															Wellhead Completion			Pitless adapter manufacturer			BAKER			Model 531					
															☐ Casing Protection			☐ 12 in. above grade											
															☐ At-grade (Environmental Wells and Borings ONLY)														
															Grouting Information			Well Grouted? ☒ Yes ☐ No ☐ Not Specified											
															Material			Amount			From			To					
															neat cement			5 Sacks						ft. 260 ft.					
															Nearest Known Source of Contamination			70 feet			North Direction						Sewer Type		
															Well disinfected upon completion?			☒ Yes ☐ No											
															Pump ☒ Not Installed			Date Installed											
															Manufacturer's name														
															Model Number			HP			Volt								
															Length of drop pipe			ft			Capacity			g.p. Typ					
															Abandoned			Does property have any not in use and not sealed well(s)?			☐ Yes ☒ No								
															Variance			Was a variance granted from the MDH for this well?			☐ Yes ☒ No								
															Miscellaneous			First Bedrock			Aquifer								
															Last Strat			Depth to Bedrock			ft								
															Located by														
															Locate Method														
															System			UTM - NAD83, Zone 15, Meters			X			Y					
															Unique Number Verification						Input Date								
															Angled Drill Hole														
															Well Contractor			Tim Butterfield Drilling, Inc.			2660			MAGNUSON, D.					
															Licensee Business			Lic. or Reg. No.			Name of Driller								
Minnesota Well Index Report										817860					Printed on 10/02/2026 HE-01205-15														