

819567		County Pipestone Quad Edgerton Quad ID 43B	MINNESOTA DEPARTMENT OF HEALTH WELL AND BORING REPORT Minnesota Statutes Chapter 1031		Entry Date 01/09/2018 Update Date 03/28/2018 Received Date 12/07/2017	
Well Name Township Range Dir Section Subsection HULSTEIN, CAL 106 44 W 16 CCBDBD Elevation 1677 Elev. Method LiDAR 1m DEM (MNDNR)			Well Depth Depth Completed Date Well Completed 33 ft. 32 ft. 09/20/2017 Drill Method Non-specified Rotary Drill Fluid			
Address Contact 503 MAIN ST W PIPESTONE MN 56164			Use domestic Status Active			
Stratigraphy Information Geological Material From To (ft.) Color Hardness TOP SOIL 0 1 BLACK HARD GRAVEL 1 6 YELLOW HARD CLAY 6 15 YELLOW HARD GRAVEL 15 20 YELLOW HARD CLAY 20 33 GRAY HARD			Well Hydrofractured? Yes ☐ No ☐ From To			
			Casing Type Single casing Joint Drive Shoe? Yes ☐ No ☐ Above/Below			
			Casing Diameter Weight 5 in. To 32 ft. lbs./ft.			
			Open Hole From ft. To ft.			
			Screen? ☒ Type plastic Make Diameter Slot/Gauze Length Set 5 in. 16 10 ft. 12 ft. 22 ft.			
			Static Water Level 9 ft. land surface Measure 09/20/2017			
			Pumping Level (below land surface) 20 ft. 10 hrs. Pumping at 15 g.p.m.			
			Wellhead Completion Pitless adapter manufacturer MONITOR Model ☐ Casing Protection ☐ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)			
			Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To bentonite ft. 12 ft.			
			Nearest Known Source of Contamination 200 feet North Direction Barnyard Type Well disinfected upon completion? ☐ Yes ☐ No			
Pump ☐ Not Installed Date Installed 09/20/2017 Manufacturer's name GOULDS Model Number 25GS15 HP 1.5 Volt 230 Length of drop pipe 20 ft Capacity 25 g.p. Typ Submersible						
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No						
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No						
Miscellaneous First Bedrock Aquifer Quat. buried Last Strat clay-gray Depth to Bedrock ft Located by Minnesota Department of Health Locate Method GPS SA Off (averaged) (15 meters) System UTM - NAD83, Zone 15, Meters X 247965 Y 4874634 Unique Number Verification Info/GPS from data Input Date 10/04/2017						
Angled Drill Hole						
Well Contractor Spartz and Sons Well Co. 1413 SPARTZ, D Licensee Business Lic. or Reg. No. Name of Driller						
Remarks						
Minnesota Well Index Report		819567		Printed on 10/02/2026 HE-01205-15		