

821686

County Hubbard
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 07/21/2017
Update Date 07/21/2017
Received Date 08/31/2016

Well Name RD OFFUTT CO.	Township 139	Range 34	Dir W	Section 24	Subsection CCB
Elevation	Elev. Method				
Address					
Well 12506 209TH AV PARK RAPIDS MN 56470					
Contact 15357 US 72 PARK RAPIDS MN 56470					
Stratigraphy Information					
Geological Material		From	To (ft.)	Color	Hardness
SAND		0	38	BROWN	SOFT
CLAY		38	136	GRAY	MEDIUM
SAND		136	157	GRAY	SOFT
Well Depth 157 ft. Depth Completed 157 ft. Date Well Completed 08/24/2016					
Drill Method Non-specified Rotary		Drill Fluid Bentonite			
Use domestic				Status	Active
Well Hydrofractured?		Yes ☐	No ☒	From	To
Casing Type Single casing		Joint			
Drive Shoe?		Yes ☐	No ☒	Above/Below	
Casing Diameter		Weight		Hole Diameter	
4 in. To		153 ft. 1 lbs./ft.		6.7 in. To 157 ft.	
Open Hole From ft. To ft.					
Screen? ☒		Type stainless		Make JOHNSON	
Diameter		Slot/Gauze Length		Set	
4 in.		15 ft.		153 ft. 157 ft.	
Static Water Level					
33 ft.		null		Measure 08/23/2016	
Pumping Level (below land surface)					
152 ft.		1 hrs. Pumping at		35 g.p.m.	
Wellhead Completion					
Pitless adapter manufacturer		MONITOR		Model SNAPPY	
☐ Casing Protection		☒ 12 in. above grade			
☐ At-grade (Environmental Wells and Borings ONLY)					
Grouting Information		Well Grouted? ☒ Yes ☐ No ☐ Not Specified			
Material		Amount		From To	
other		4 Sacks		ft. 50 ft.	
Nearest Known Source of Contamination					
130 feet		North Direction		Septic tank/drain field Type	
Well disinfected upon completion?		☒ Yes ☐ No			
Pump ☐ Not Installed		Date Installed		08/24/2016	
Manufacturer's name		PENTEK			
Model Number		S10P4IP071	HP	0.75	Volt 123
Length of drop pipe		80 ft	Capacity	10 g.p.	Typ Submersible
Abandoned					
Does property have any not in use and not sealed well(s)?				☐ Yes	☒ No
Variance					
Was a variance granted from the MDH for this well?				☐ Yes	☒ No
Miscellaneous					
First Bedrock		Aquifer			
Last Strat		Depth to Bedrock		ft	
Located by					
Locate Method					
System		UTM - NAD83, Zone 15, Meters		X	Y
Unique Number Verification		Input Date			
Angled Drill Hole					
Well Contractor					
Elsner Well Drilling, Inc.		1374		JOHNSON, J	
Licensee Business		Lic. or Reg. No.		Name of Driller	
Remarks					
K PACKER FITTING ON SCREEN					
WELL GROUTED WITH VOLCLAY 2					