

824848

County Wright
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date06/04/2018
Update Date06/04/2018
Received Date12/13/2017

Well Name SANDBERG,	Township 121	Range 26	Dir W	Section 34	Subsection DBD	Well Depth 119 ft.	Depth Completed 119 ft.	Date Well Completed 11/10/2017							
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Water								
Address						Use domestic	Status Active								
						Well Hydrofractured?		Yes ☐	No ☒	From	To				
						Casing Type Single casing		Joint Glued							
Stratigraphy Information Geological MaterialFromTo (ft.)ColorHardness CLAY020YELLOW CLAY + SAND2065YELLOW CLAY6579GRAY SAND + GRAVEL79119GRAY						Drive Shoe?	Yes ☐	No ☒	Above/Below						
						Casing Diameter		Weight		Hole Diameter					
						3 in. To		112 ft. 119 lbs./ft.		8.2 in. To 60 ft. 6.5 in. To 119 ft.					
						Open Hole						From	ft.	To	ft.
						Screen?	☒	Type	plastic		Make JAYCO				
						Diameter	Slot/Gauze	Length		Set					
						3 in.	15	7 ft.		112 ft.		119 ft.			
						Static Water Level									
						73 ft.		land surface		Measure		11/10/2017			
						Pumping Level (below land surface)									
		ft.		hrs.		Pumping at		35 g.p.m.							
Wellhead Completion															
Pitless adapter manufacturer						MASS		Model	4"						
☐ Casing Protection						☒ 12 in. above grade									
☐ At-grade (Environmental Wells and Borings ONLY)															
Grouting Information						Well Grouted? ☒ Yes ☐ No ☐ Not Specified									
Material		Amount		From		To									
bentonite		7 Sacks		8 ft.		83 ft.									
Nearest Known Source of Contamination															
feet		Direction						Type							
Well disinfected upon completion?						☒ Yes ☐ No									
Pump ☐ Not Installed						Date Installed		11/10/2017							
Manufacturer's name						SCHAFFER									
Model Number		HP		0.5		Volt		230							
Length of drop pipe		80 ft		Capacity		10 g.p.		Typ Submersible							
Abandoned															
Does property have any not in use and not sealed well(s)?						☐ Yes ☒ No									
Variance															
Was a variance granted from the MDH for this well?						☐ Yes ☒ No									
Miscellaneous															
First Bedrock				Aquifer											
Last Strat				Depth to Bedrock				ft							
Located by															
Locate Method															
System		UTM - NAD83, Zone 15, Meters		X		Y									
Unique Number Verification						Input Date									
Angled Drill Hole															
Well Contractor															
Stevens Drilling and				2255		JOHNSON, R.									
Licensee Business				Lic. or Reg. No.		Name of Driller									