

826176

County Anoka
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 05/17/2018
Update Date 05/17/2018
Received Date 02/14/2017

Well Name CARRINGTON	Township 33	Range 23	Dir Section W 3	Subsection BBD	Well Depth 135 ft.	Depth Completed 135 ft.	Date Well Completed 12/02/2016
Elevation	Elev. Method				Drill Method Non-specified Rotary	Drill Fluid Qwik gel	
Address					Use domestic	Status Active	
Well 22722 BATAAN ST NE BETHEL MN 55005					Well Hydrofractured? Yes ☐ No ☒ From To		
Contact CEDAR MN 55011					Casing Type Single casing Joint Threaded		
Stratigraphy Information					Drive Shoe? Yes ☒ No ☐ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter	
SAND		0	57	BROWN	SOFT	4 in. To 107 ft. lbs./ft. 8.5 in. To 50 ft.	
CLAY + GRAVEL		57	71	BROWN	HARD	6.2 in. To 103 ft.	
SAND		71	78	RED	MEDIUM	4 in. To 135 ft.	
COARSE GRAVEL		78	94	BRN/BLK	HARD		
SHALE + GRAVEL		94	99	BROWN	MEDIUM		
SHALE + SANDROCK		99	135	GRN/BRN	HARD		
					Open Hole From 107 ft. To 135 ft.		
					Screen? ☐ Type Make		
					Static Water Level		
					21 ft. land surface Measure 12/05/2016		
					Pumping Level (below land surface)		
					50 ft. 6 hrs. Pumping at 60 g.p.m.		
					Wellhead Completion		
					Pitless adapter manufacturer WHITEWATER Model SV4X5.5 CF		
					☐ Casing Protection ☒ 12 in. above grade		
					☐ At-grade (Environmental Wells and Borings ONLY)		
					Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
					Material Amount From To		
					bentonite 3 Sacks ft. 50 ft.		
					Nearest Known Source of Contamination		
					75 feet Southwes Direction Septic tank/drain field Type		
					Well disinfected upon completion? ☐ Yes ☐ No		
					Pump ☐ Not Installed Date Installed 12/05/2016		
					Manufacturer's name STA-RITE		
					Model Number 10P4D02J- HP 0.75 Volt 230		
					Length of drop pipe 53 ft Capacity 15 g.p. Typ Submersible		
					Abandoned		
					Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
					Variance		
					Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
					Miscellaneous		
					First Bedrock Aquifer		
					Last Strat Depth to Bedrock ft		
					Located by		
					Locate Method		
					System UTM - NAD83, Zone 15, Meters X Y		
					Unique Number Verification Input Date		
					Angled Drill Hole		
					Well Contractor		
					Art Torgerson and Son Well 1479 TORGERSON, S.		
					Licensee Business Lic. or Reg. No. Name of Driller		
Remarks							