

826646

County Carver
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 08/09/2018
Update Date 08/09/2018
Received Date 05/03/2018

Well Name UTOFT, DAVID	Township 116	Range 23	Dir W	Section 6	Subsection ACA
Elevation	Elev. Method				
Address					
Well 6548 ASTER TR EXCELSIOR MN 55331					
Contact 5428 MORGAN AV S MINNEAPOLIS MN 55419					
Stratigraphy Information					
Geological Material	From	To (ft.)	Color	Hardness	
CLAY	0	11	BROWN	MEDIUM	
SAND/CLAY	11	29	BROWN	SOFT	
CLAY/SAND	29	78	GRAY	MEDIUM	
GRAVEL/CLAY	78	93	GRAY	MEDIUM	
SANDY CLAY	93	105	GRAY	SOFT	
FINE SAND	105	160	GRAY	SOFT	
GRAVEL/SAND	160	168	VARIED	MEDIUM	

Well Depth 168 ft.	Depth Completed 168 ft.	Date Well Completed 02/26/2018			
Drill Method	Non-specified Rotary		Drill Fluid	Bentonite	
Use	domestic				Status Active
Well Hydrofractured? Yes ☐ No ☒ From To					
Casing Type Single casing Joint					
Drive Shoe? Yes ☐ No ☐ Above/Below					
Casing Diameter		Weight		Hole Diameter	
4 in. To 160 ft.		lbs./ft.		8 in. To 50 ft. 6.7 in. To 168 ft.	
Open Hole From ft. To ft.					
Screen? ☒ Type stainless Make JOHNSON					
Diameter		Slot/Gauze		Length Set	
2 in.		10		4 ft. 160 ft. 168 ft.	
Static Water Level					
97 ft.		null		Measure 02/26/2018	
Pumping Level (below land surface)					
150 ft.		2 hrs.		Pumping at 40 g.p.m.	
Wellhead Completion					
Pitless adapter manufacturer		WHITEWATER		Model	
☐ Casing Protection		☒ 12 in. above grade			
☐ At-grade (Environmental Wells and Borings ONLY)					
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified					
Material		Amount		From To	
cuttings				50 ft. 160 ft.	
bentonite		3 Sacks		ft. 50 ft.	
Nearest Known Source of Contamination					
75 feet		East Direction		Sewer Type	
Well disinfected upon completion? ☐ Yes ☐ No					
Pump ☐ Not Installed Date Installed 03/02/2018					
Manufacturer's name SCHAEFER					
Model Number		HP 1.5		Volt 230	
Length of drop pipe 126 ft		Capacity		g.p. Typ Submersible	
Abandoned					
Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No					
Variance					
Was a variance granted from the MDH for this well? ☐ Yes ☒ No					
Miscellaneous					
First Bedrock		Aquifer			
Last Strat		Depth to Bedrock		ft	
Located by					
Locate Method					
System UTM - NAD83, Zone 15, Meters		X		Y	
Unique Number Verification				Input Date	
Angled Drill Hole					
Well Contractor					
Don Stodola Well Drilling		1691		STODOLA, M.	
Licensee Business		Lic. or Reg. No.		Name of Driller	

Minnesota Well Index Report	826646	Printed on 08/13/2026 HE-01205-15
-----------------------------	--------	--------------------------------------