Minnesota Unique Well Number

828926

County Olmsted
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 06/02/2020
Update Date 06/02/2020
Received Date 09/25/2019

Well Name	Township	Range	Dir	Section	Subsection
EVERS, FAITH	105	13	W	33	BAA

Elevation **Elev. Method**

Address

C/W 11117 1 CH SE STEWARTVILLE MN 55976

Stratigraphy Information

Geological Material	From	To (ft.)	Color	Hardness
SANDY CLAY	0	20	BROWN	SOFT
SHALE	20	40	GRAY	MEDIUM
SAND	40	47	BROWN	SOFT
LIMESTONE	47	248	GRAY	HARD
SHALE	248	292	BLUE	MEDIUM
LIMESTONE	292	310	BROWN	HARD
SHALE	310	316	GREEN	MEDIUM
SANDSTONE	316	376	GRAY	MEDIUM

Remarks

Well Depth 376 ft. **Depth Completed** 376 ft. **Date Well Completed** 09/04/2019

Drill Method Non-specified Rotary **Drill Fluid**

Use domestic **Status** Active

Well Hydrofractured? Yes ☐ No ☒ **From** **To**

Casing Type Step down **Joint** Welded

Drive Shoe? Yes ☒ No ☐ **Above/Below**

Casing Diameter			Weight		Hole Diameter		
8	in. To 48	ft.		lbs./ft.	8	in. To 355	ft.
8	in. To 48	ft.		lbs./ft.	4	in. To 376	ft.
4	in. To 355	ft.	10.79	lbs./ft.			

Open Hole From 355 ft. To 376 ft.

Screen? ☐ **Type** **Make**

Static Water Level

296 ft. land surface Measure 09/03/2019

Pumping Level (below land surface)

ft. hrs. Pumping at g.p.m.

Wellhead Completion

Pitless adapter manufacturer MONITOR Model 4 X 6

☐ Casing Protection ☐ 12 in. above grade

☐ At-grade (Environmental Wells and Borings ONLY)

Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified

Material	Amount		From	To
bentonite	3	Sacks	0 ft.	48 ft.
pearock	1	Cubic yards	50 ft.	250 ft.
neat cement	4.6	Cubic yards	ft.	355 ft.

Nearest Known Source of Contamination

60 feet Southwes Direction Sewer Type

Well disinfected upon completion? ☒ Yes ☐ No

Pump ☐ Not Installed Date Installed 09/04/2019

Manufacturer's name GRUNDFOS

Model Number 10S15-21 HP 1.5 Volt 230

Length of drop pipe 315 ft Capacity 13 g.p. Typ Submersible

Abandoned

Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No

Variance

Was a variance granted from the MDH for this well? ☐ Yes ☒ No

Miscellaneous

First Bedrock Aquifer

Last Strat Depth to Bedrock ft

Located by

Locate Method

System UTM - NAD83, Zone 15, Meters X Y

Unique Number Verification Input Date

Angled Drill Hole

Well Contractor

Rowland Well Co., Inc. 1928 ROWLAND, S.

Licensee Business Lic. or Reg. No. Name of Driller