

831479

County Anoka
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date02/06/2020
Update Date02/06/2020
Received Date10/23/2018

Well Name SHELDON,	Township 33	Range 25	Dir W	Section 4	Subsection CCD	Well Depth 195 ft.	Depth Completed 195 ft.	Date Well Completed 12/29/2017
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Qwik gel	
Address						Use domestic	Status Active	
Well 22120 ZEOLITE ST NW NOWTHEN MN 55330						Well Hydrofractured? Yes ☐ No ☐ From To		
Stratigraphy Information						Casing Type Single casing	Joint Threaded	
						Drive Shoe? Yes ☒ No ☐	Above/Below	
Geological Material						Casing Diameter	Weight	Hole Diameter
CLAY						4 in. To	156 ft. lbs./ft.	8.7 in. To 156 ft.
CLAY/GRAVEL								4 in. To 195 ft.
GRAVEL								
CLAY/ROCKS								
SHALE								
S.S. SHALE								
SHALE								
						Open Hole From 156 ft. To 195 ft.		
						Screen? ☐	Type	Make
Static Water Level								
30 ft. land surface						Measure	12/28/2017	
Pumping Level (below land surface)								
50 ft. 3 hrs. Pumping at						30	g.p.m.	
Wellhead Completion								
Pitless adapter manufacturer ☐ Casing Protection						BAKER ☒ 12 in. above grade	Model SNAPPY	
						☐ At-grade (Environmental Wells and Borings ONLY)		
Grouting Information						Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
Material						Amount	From	To
neat cement						30 Sacks	ft.	156 ft.
Nearest Known Source of Contamination								
50 feet South Direction						Septic tank/drain field Type		
Well disinfected upon completion?						☒ Yes ☐ No		
Pump						☐ Not Installed	Date Installed	01/04/2018
Manufacturer's name						GRUNDFOS		
Model Number						22SQE15-	HP	1.5
Length of drop pipe						60 ft	Capacity	22 g.p.
						Typ	Submersible	
Abandoned								
Does property have any not in use and not sealed well(s)?						☐ Yes ☒ No		
Variance								
Was a variance granted from the MDH for this well?						☐ Yes ☒ No		
Miscellaneous								
First Bedrock						Aquifer		
Last Strat						Depth to Bedrock ft		
Located by								
Locate Method								
System						UTM - NAD83, Zone 15, Meters	X	Y
Unique Number Verification						Input Date		
Angled Drill Hole								
Well Contractor								
EH Renner and Sons, Inc.						1431	PRAUGHT, L	
Licensee Business						Lic. or Reg. No.	Name of Driller	