

845045

County Hubbard
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 12/14/2023
Update Date 12/14/2023
Received Date 07/10/2023

Well Name ELLIOT, JILL	Township 141	Range 34	Dir W	Section 25	Subsection CCC	Well Depth 24 ft.	Depth Completed 24 ft.	Date Well Completed 06/06/2023
Elevation	Elev. Method					Drill Method Driven	Drill Fluid Other	
Address						Use domestic	Status Active	
Contact 33610 38 ST MOORHEAD MN 56560						Well Hydrofractured? Yes ☐ No ☒ From To		
Well 22068 7 CO PARK RAPIDS MN 56470						Casing Type Single casing Joint Unknown		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☐ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter 1.2 in. To 21 ft. lbs./ft.		
TOPSOIL		0	1	BLACK	SOFT	Hole Diameter 1.2 in. To ft.		
SAND		1	24	BROWN	SOFT			
Open Hole						From	ft.	To
						ft.		
Screen? ☒						Type stainless	Make JOHNSON	
Diameter						Slot/Gauze	Length	Set
1.2 in.						10	3 ft.	21 ft. 24 ft.
Static Water Level								
5 ft. land surface						Measure	06/06/2023	
Pumping Level (below land surface)								
5 ft. 2 hrs. Pumping at						20	g.p.m.	
Wellhead Completion								
Pitless adapter manufacturer						Model		
☐ Casing Protection						☒ 12 in. above grade		
☐ At-grade (Environmental Wells and Borings ONLY)								
Grouting Information						Well Grouted?	☒ Yes	☐ No
						☐ Not Specified		
Material						Amount	From	To
bentonite							ft.	ft.
Nearest Known Source of Contamination								
20 feet North Direction						Sewer Type		
Well disinfected upon completion?						☐ Yes	☐ No	
Pump ☐ Not Installed						Date Installed	06/06/2023	
Manufacturer's name						STA-RITE		
Model Number						HUC	HP	0.5
Length of drop pipe						ft	Capacity	12 g.p.
						Typ	Jet	
Abandoned								
Does property have any not in use and not sealed well(s)?						☐ Yes	☒ No	
Variance								
Was a variance granted from the MDH for this well?						☐ Yes	☒ No	
Miscellaneous								
First Bedrock						Aquifer		
Last Strat						Depth to Bedrock		
						ft		
Located by								
Locate Method								
System						UTM - NAD83, Zone 15, Meters	X	Y
Unique Number Verification						Input Date		
Angled Drill Hole								
Well Contractor								
Ehresmann Water Wells And						1450	EHRESMANN, D.	
Licensee Business						Lic. or Reg. No.	Name of Driller	