

850269

County Houston
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 01/10/2025
Received Date 11/19/2024

Well Name RILEY, SHEILA	Township 104	Range 4	Dir W	Section 11	Subsection ACA	Well Depth 126 ft.	Depth Completed 126 ft.	Date Well Completed 03/25/2024
Elevation	Elev. Method					Drill Method Cable Tool	Drill Fluid Water	
Address						Use domestic	Status Active	
Well 340 SHOREACRES RD LA CRESCENT MN 55947						Well Hydrofractured? Yes ☐ No ☒ From To		
Contact W5947 WOODLAND DR LA CROSSE WI 54601						Casing Type Single casing Joint Welded		
Stratigraphy Information						Drive Shoe? Yes ☒ No ☐ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter		
SAND		0	32	BROWN	SOFT	4 in. To 118 ft. 10.79 lbs./ft. 4 in. To 126 ft.		
SAND		32	98	GRAY	SOFT			
SAND & GRAVEL		98	126	RED/BRN	SOFT			
						Open Hole From ft. To ft.		
						Screen? ☒ Type Make JOHNSON		
						Diameter Slot/Gauze Length Set		
						4 in. 10 8 ft. 118 ft. 126 ft.		
						Static Water Level		
						14 ft. land surface Measure 03/20/2024		
						Pumping Level (below land surface)		
						20 ft. 48 hrs. Pumping at 20 g.p.m.		
						Wellhead Completion		
						Pitless adapter manufacturer BAKER Model		
						☐ Casing Protection ☒ 12 in. above grade		
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information Well Grouted? ☐ Yes ☐ No ☒ Not Specified		
						Nearest Known Source of Contamination		
						54 feet Southeast Direction Sewer Type		
						Well disinfected upon completion? ☒ Yes ☐ No		
						Pump ☐ Not Installed Date Installed 03/20/2024		
						Manufacturer's name GOULDS		
						Model Number HP 1 Volt 230		
						Length of drop pipe 40 ft Capacity 18 g.p. Typ Submersible		
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
						Miscellaneous		
						First Bedrock Aquifer		
						Last Strat Depth to Bedrock ft		
						Located by		
						Locate Method		
						System UTM - NAD83, Zone 15, Meters X Y		
						Unique Number Verification Input Date		
						Angled Drill Hole		
						Well Contractor		
						Garys Pump And Well 1761 FRAUENKRON, B		
						Licensee Business Lic. or Reg. No. Name of Driller		